
EP heating manifolds

uponor

Job name:	Location:
Engineer:	Date submitted:
Contractor:	Submitted by:
Manufacturer's representative:	Approved by:

Technical data	
Material	Engineered Polymer
Subcomponent Material	Manifold: PA66-GF30
	Valve Insert, Handwheels: POM
	Metal Inserts: Brass C38500
	Axel: Stainless Steel
	Spring: Stainless Steel
	O-ring: EPDM
Loop Cv	1.4 Cv
End type 1	ISO 228-G 1-1/4"
End type 2	ISO 228-G 3/4"
Temp/pressure ratings	140 °F (60 °C) at 87 psi (6 bar)
	158 °F (70 °C) at 72 psi (5 bar)
	176 °F (80 °C) at 58 psi (4 bar)
	194 °F (90 °C) at 44 psi (3 bar)
Max. fluid flow rate	15.4 gpm
Prop 65 label required?	Yes
Product information and appl	ication use



The Engineered Polymer (EP) Heating Manifold Assemblies feature isolation valves and balancing valves with flow meters (0-1 gpm), and come fully assembled, ready for installation in hydronic radiant heating and cooling systems. Use only propylene glycol in radiant systems with EP Heating the feature should be a shoul

Manifolds; never use ethylene glycol.

Part name	Part no.	A [mm]	B [mm]	C [mm]	D [mm]	E [mm]	F [mm]	G [mm]	H [mm]	Weight per UOM [kg/UOM]
EP Heating Manifold Assembly with Flow Meter, 2-loop	A2670201	250.96	360.28	79	50	111.50	30	46	-	1.588
EP Heating Manifold Assembly with Flow Meter, 3-loop	A2670301	300.97	360.28	79	50	111.51	30	46	100	1.887
EP Heating Manifold Assembly with Flow Meter, 4-loop	A2670401	350.96	360.28	79	50	111.50	30	46	150	2.186
EP Heating Manifold Assembly with Flow Meter, 5-loop	A2670501	400.96	360.28	79	50	111.50	30	46	200	2.486
EP Heating Manifold Assembly with Flow Meter, 6-loop	A2670601	450.96	360.28	79	50	111.50	30	46	250	2.785
EP Heating Manifold Assembly with Flow Meter, 7-loop	A2670701	500.96	360.28	79	50	111.50	30	46	300.04	3.084
EP Heating Manifold Assembly with Flow Meter, 8-loop	A2670801	550.96	360.28	79	50	111.50	30	46	350	3.384

Installation

Do not use thread sealant on connections. Carriers present in these compounds can crack the plastic port connections, resulting in leaks and water damage. For additional information, refer to the EP Heating Manifold Instruction Sheet. Note: Use only propylene glycol in radiant heating and cooling systems with EP Heating Manifolds; never use ethylene glycol. Refer to the EP Heating Manifold Installation Guide for a complete chemicals list.

Related applications

Radiant Heating and Cooling Systems

Permafrost Protection Systems

Turf Conditioning Systems

Notes

Compatible Actuators:

A3023522 Thermal Actuator, four-wire; A3030522 Two-wire Thermal Actuator for EP Heating Manifolds

Footnotes	Contact information			
	Uponor Inc.	Uponor Ltd.		
	5925 148th Street West	6510 Kennedy Road		
	Apple Valley, MN 55124	Mississauga, ON L5T 2X4		
	T 800.321.4739	T 888.594.7726		
	F 952.891.2008	F 800.638.9517		