

# EP heating manifolds

Project information	
Job name:	Location:
Engineer:	Date submitted:
Contractor:	Submitted by:
Manufacturer's representative:	Approved by:

### Technical data

Material Engineered Polymer
Subcomponent Material Manifold: PA66-GF30
Valve Insert, Handwheels: POM
Metal Inserts: Brass C38500

Axel: Stainless Steel Spring: Stainless Steel O-ring: EPDM


Loop Cv 1.4 Cv
End type 1 ISO 228-G 1-1/4"
End type 2 ISO 228-G 3/4"

Temp/pressure ratings 140 °F (60 °C) at 87 psi (6 bar) 158 °F (70 °C) at 72 psi (5 bar) 176 °F (80 °C) at 58 psi (4 bar) 194 °F (90 °C) at 44 psi (3 bar)

Max. fluid flow rate 15.4 gpm Prop 65 label required? Yes

#### Product information and application use

The Engineered Polymer (EP) Heating Manifold Assemblies feature isolation valves and balancing valves with flow meters (0-1 gpm), and come fully assembled, ready for installation in hydronic radiant heating and cooling systems. Use only propylene glycol in radiant systems with EP Heating Manifolds; never use ethylene glycol.





Part name	Part no.	A [mm]	B [mm]	C [mm]	D [mm]	E [mm]	F [mm]	G [mm]	H [mm]	Weight per UOM [kg/UOM]
EP Heating Manifold Assembly with Flow Meter, 2-loop	A2670201	250.96	360.28	79	50	111.50	30	46	-	1.588
EP Heating Manifold Assembly with Flow Meter, 3-loop	A2670301	300.97	360.28	79	50	111.51	30	46	100	1.887
EP Heating Manifold Assembly with Flow Meter, 4-loop	A2670401	350.96	360.28	79	50	111.50	30	46	150	2.186
EP Heating Manifold Assembly with Flow Meter, 5-loop	A2670501	400.96	360.28	79	50	111.50	30	46	200	2.486
EP Heating Manifold Assembly with Flow Meter, 6-loop	A2670601	450.96	360.28	79	50	111.50	30	46	250	2.785
EP Heating Manifold Assembly with Flow Meter, 7-loop	A2670701	500.96	360.28	79	50	111.50	30	46	300.04	3.084
EP Heating Manifold Assembly with Flow Meter, 8-loop	A2670801	550.96	360.28	79	50	111.50	30	46	350	3.384

## Installation Related applications

Do not use thread sealant on connections. Carriers present in these compounds can crack the plastic port connections, resulting in leaks and water damage. For additional information, refer to the EP Heating Manifold Instruction Sheet. Note: Use only propylene glycol in radiant heating and cooling systems with EP Heating Manifolds; never use ethylene glycol. Refer to the EP Heating Manifold Installation Guide for a complete chemicals list.

Radiant Heating and Cooling Systems
Permafrost Protection Systems

Turf Conditioning Systems

#### Notes

Compatible Actuators:

A3023522 Thermal Actuator, four-wire; A3030522 Two-wire Thermal Actuator for EP Heating Manifolds

Footnotes	Contact information				
	Uponor Inc.	Uponor Ltd.			
	5925 148th Street West	6510 Kennedy Road			
•	Apple Valley, MN 55124	Mississauga, ON L5T 2X4			
	T 800.321.4739	T 888.594.7726			
	F 952.891.2008	F 800.638.9517			