

SetPoint 521 programmable thermostats

Project Information

Job name:	Location:
Engineer:	Date submitted:
Contractor:	Submitted by:
Manufacturer's representative:	Approved by:

Technical data

Prop 65 label required? Yes

Product information and application use

The SetPoint 521, Programmable Thermostat with Floor Sensor is designed to provide three different modes of operation: single-stage heating, two stages of heating with a fan, or one stage of heating and one stage of cooling with a fan. Auxiliary sensors may be added to measure floor, outdoor or room temperature. Uponor Floor Sensor (A3040079) is included to measure floor temperature to protect the floor from overheating and enhance comfort. Programmable schedules support either a 7-day or 24-hour schedule with two or four events per day.



Part name	Part no.	Current draw max. [A]	Operating voltage [V]	Operating voltage AC [VAC]	Weight per UOM [lbs/UOM]
Cover Plate for SetPoint 521 Programmable Thermostat	A3040012	-	-	-	-
Floor Sensor, replacement part	A3040079	0.08	30	24	0.1
SetPoint 521, Programmable Thermostat with floor sensor	A3040521	0.08	30	24	0.6

Part name	Part no.	Codes	Standards	Listings
SetPoint 521 programmable thermostats	All	-	-	-
In addition, the following parts have additional codes, standards, or listings:				
Floor Sensor, replacement part	A3040079			Thermostat:
SetPoint 521, Programmable Thermostat with floor sensor	A3040521			Thermostat:

Installation

Install the thermostat on an interior wall of the desired zone approximately 5 feet above the floor. Do not mount the thermostat on a location that may be affected by localized heat sources or cold drafts. It may be necessary to install a draft barrier behind the thermostat to prevent air from blowing through the wiring hole which can affect the thermostat's built-in sensor. Refer to the Uponor SetPoint 521 Programmable Thermostat with Floor Sensor Installation and Operation Manual for more information.

Related applications

Radiant Heating and Cooling Systems

Notes

Floor Sensor (A3040079):
NTC thermistor, 10 k at 77°F (25°C ±0.2°C)

Footnotes

Contact information

-	<p>Uponor Inc. 5925 148th Street West Apple Valley, MN 55124 T 800.321.4739 F 952.891.2008</p>	<p>Uponor Ltd. 6510 Kennedy Road Mississauga, ON L5T 2X4 T 888.594.7726 F 800.638.9517</p>
---	--	--