Repair couplings

| Project information | | | | |
|--------------------------------|-----------------|--|--|--|
| Job name: | Location: | | | |
| Engineer: | Date submitted: | | | |
| Contractor: | Submitted by: | | | |
| Manufacturer's representative: | Approved by: | | | |

Technical data

Material Brass

End type 1 Compression 5/16"
End type 2 Compression 5/16"

Temp/pressure ratings $\,$ 73 °F (23 °C) at 160 psi (11 bar)

180 °F (82 °C) at 100 psi (6.9 bar) 200 °F (93 °C) at 80 psi (5.5 bar)

Prop 65 label required? Yes

Product information and application use

Use 5 /16" Repair Coupling to connect 5 /16" Wirsbo hePEX $^{\text{TM}}$ tubing. This one-piece repair coupling comes as an assembly. No other fittings are necessary.



| | Part name | | Part no. | A [inch] | B [inch] | C [inch] | [ibs/UOM] |
|--------------------|-------------------|----------|----------|-----------|-----------|------------|-----------|
| | 5/16" Repair Coup | bling | A4010313 | 1.736 | 0.86 | 0.86 | 0.15 |
| | | | | | | | |
| Part name Part no. | | Part no. | Codes | Standards | | Listings | |
| | Repair couplings | A4010313 | - | | ASTM F877 | cNSFus-rfh | |

| Installation | Related applications | | | | | |
|--|-------------------------------------|--|--|--|--|--|
| Slide the nut and compression insert onto the tubing. Place the fitting inside the tubing and thread | Radiant Heating and Cooling Systems | | | | | |
| nut onto the fitting. For more information, refer to the Uponor Radiant Floor Heating Installation ndbook. | Permafrost Protection Systems | | | | | |
| | Turf Conditioning Systems | | | | | |

| Footnotes | Contact information | | |
|-----------|------------------------|-------------------------|--|
| | Uponor Inc. | Uponor Ltd. | |
| | 5925 148th Street West | 6510 Kennedy Road | |
| | Apple Valley, MN 55124 | Mississauga, ON L5T 2X4 | |
| | T 800.321.4739 | T 888.594.7726 | |
| | F 952.891.2008 | F 800.638.9517 | |