

ProPEX lead-free (LF) brass fire sprinkler accessories

Project information

| | |
|--------------------------------|-----------------|
| Job name: | Location: |
| Engineer: | Date submitted: |
| Contractor: | Submitted by: |
| Manufacturer's representative: | Approved by: |

Technical data

Prop 65 label required? Yes



| Part name | Part no. | A [Inch] | B [Inch] | C [Inch] | Material group | Subcomponent Material | Equivalent length branch [ft] | End Type 1 | Operating Temperature 1 [°F] | Operating Temperature 2 [°F] | Operating Temperature 3 [°F] |
|---|----------|----------|----------|----------|----------------|---|-------------------------------|------------|------------------------------|------------------------------|------------------------------|
| Fire Sprinkler Adapter Mounting Bracket, 3/4" and 1 | A7750700 | 3.171 | 2.484 | 1.839 | Metal | 1050 Annealed (spheroidized) spring steel | - | - | - | - | - |
| Fire Sprinkler Adapter Push-on Nut, 25/pkg. | F7000005 | 2.125 | 0.233 | 2.125 | Steel | - | 0 | ProPEX | 73 | 180 | 200 |

| Part name | Part no. | Weight per UOM [lbs/UOM] |
|---|----------|--------------------------|
| Fire Sprinkler Adapter Mounting Bracket, 3/4" and 1 | A7750700 | 0.17 |
| Fire Sprinkler Adapter Push-on Nut, 25/pkg. | F7000005 | 0.01 |

| Part name | Part no. | Codes | Standards | Listings |
|--|----------|-------|-----------|----------|
| ProPEX lead-free (LF) brass fire sprinkler accessories | All | - | UL 1821 | - |

Installation

-

Related applications

AquaSAFE™ Fire Safety Systems

Footnotes

-

Contact information

Uponor Inc.
5925 148th Street West
Apple Valley, MN 55124
T 800.321.4739
F 952.891.2008

Uponor Ltd.
6510 Kennedy Road
Mississauga, ON L5T 2X4
T 888.594.7726
F 800.638.9517