

ProPEX lead-free (LF) brass ice maker boxes

Project information

Job name:	Location:
Engineer:	Date submitted:
Contractor:	Submitted by:
Manufacturer's representative:	Approved by:

Technical data

Temp/pressure ratings	73 °F (23 °C) at 160 psi (11 bar)
	180 °F (82 °C) at 100 psi (6.9 bar)
	200 °F (93 °C) at 80 psi (5.5 bar)

Product information and application use

The ProPEX® Ice Maker Box with Support Brackets, 1/2" (LF Brass) Valve with snap-in frame includes a 1/2" lead-free brass valve with 1/4" O.D. compression connection.1 This high-impact box is an aesthetic, convenient option for connecting to standard ice maker tubing. Two support brackets are provided for easy mounting.

Note: Temperature and pressure ratings stated are hydrostatic ratings. For domestic hot-water (DHW) and DHW recirculation installations, operating conditions should not exceed 140°F (60°C) at 80 psi (5.5 bar) in accordance with ASTM F2023. For additional information regarding application-specific temperature and pressure ratings, refer to the Uponor PEX Piping Systems Design and Installation Manual.



Part name	Part no.	Material group	End Type 1	End Type 2	Prop 65 label required?
ProPEX Ice Maker Box with Support Brackets, 1/2" LF Brass Valve	LF5955025	-	ProPEX	Compression	Yes
1/4" Insert (stainless steel)	F5400250	Stainless Steel	-	-	-

Part name	Part no.	Codes	Standards	Listings
ProPEX lead-free (LF) brass ice maker boxes	All	UPC IPC NPC of Canada	NSF-372 ASME A112.18.1 ASTM F877 ASTM F1960 CSA B125 CSA B137.5 NSF-61 NSF-14	cNSFus-pw-G U.P.Code

Installation

Mount in wall cavity at the desired location (e.g., behind refrigerator) using the supplied mounting brackets or directly to studs. For more information, refer to the AquaPEX® Professional Plumbing Installation Guide.

Related applications

PEX-a Plumbing Systems

Footnotes

-

Contact information

Uponor Inc.
5925 148th Street West
Apple Valley, MN 55124
T 800.321.4739
F 952.891.2008

Uponor Ltd.
6510 Kennedy Road
Mississauga, ON L5T 2X4
T 888.594.7726
F 800.638.9517