

## Pre-insulated Uponor AquaPEX coils

Project information	
Job name:	Location:
Engineer:	Date submitted:
Contractor:	Submitted by:
Manufacturer's representative:	Approved by:

## Technical data

Material PEX

Temp/pressure ratings 73 °F (23 °C) at 160 psi (11 bar) 180 °F (82 °C) at 100 psi (6.9 bar) 200 °F (93 °C) at 80 psi (5.5 bar)

## Product information and application use

Pre-insulated Uponor AquaPEX® complies with the most recent versions of ASHRAE 90.1 and the International Energy Conservation Code (IECC). The product is available with  ${\cal V}_2$ " to  $1{\cal V}_2$ " PEX-a service pipe covered in  ${\cal V}_2$ " or 1" insulation. The insulation features manufactured-sealed seams running the entire length of the pipe for added convenience and system performance. Check with local code authorities regarding energy-code requirements for specific applications.

Note: Temperature and pressure ratings stated are hydrostatic ratings. For domestic hot-water (DHW) and DHW recirculation installations, operating conditions should not exceed 140°F (60°C) at 80 psi (5.5 bar) in accordance with ASTM F2023. For additional information regarding application-specific temperature and pressure ratings, refer to the Uponor PEX Piping Systems Design and Installation Manual.



Part name	Part no.	R value
1/2" Pre-insulated Uponor AquaPEX with 1/2" insulation, 100-ft. coil	F6040500	3.9
1/2" Pre-insulated Uponor AquaPEX with 1" insulation, 100-ft. coil	F6150500	7.5
3/4" Pre-insulated Uponor AquaPEX with 1/2" insulation, 100-ft. coil	F6040750	3.6
1" Pre-insulated Uponor AquaPEX with 1/2" insulation, 100-ft. coil	F6041000	3.4
1" Pre-insulated Uponor AquaPEX with 1" insulation, 100-ft. coil	F6151000	6.4
1 1/4" Pre-insulated Uponor AquaPEX with 1" insulation, 100-ft. coil	F6151250	6.1
2" Pre-insulated Uponor AquaPEX with 1 1/2" insulation, 75-ft. coil	F6162000	9.9
3/4" Pre-insulated Uponor AquaPEX with 1" insulation, 100-ft. coil	F6150750	7.9

Pre-insulated Uponor AquaPEX coils All  In addition, the following parts have additional	codes, standards, or listings:	IMC UPC IBC IRC NBC of Canada IPC UFGS NPC of Canada UMC NSPC	ASTM F1960 ASTM F876 ASTM F2023 ASTM E814/ULC S115 ASTM F877 CSA B137.5 CSA B214 ULC S101	IAPMO-ES ICC-ES-PMG CCMC PPI TR-4 CSA UL U.P.Code cQAlus P321
1/2" Dro insulated Unexas AsuaDEV				
1/2" Pre-insulated Uponor AquaPEX with 1/2" insulation, 100-ft. coil	1500		NSF-61 NSF-14	cNSFus-pw
1/2" Pre-insulated Uponor AquaPEX with 1" insulation, 100-ft. coil	0500		NSF-61 NSF-14	cNSFus-pw
3/4" Pre-insulated Uponor AquaPEX with 1/2" insulation, 100-ft. coil	0750		UL 1821 NSF-61 NSF-14	cNSFus-pw-fs
1" Pre-insulated Uponor AquaPEX with 1/2" insulation, 100-ft. coil	000		UL 1821 NSF-61 NSF-14	cNSFus-pw-fs
1" Pre-insulated Uponor AquaPEX with 1" insulation, 100-ft. coil	000		UL 1821 NSF-61 NSF-14	cNSFus-pw-fs
1 1/4" Pre-insulated Uponor AquaPEX with 1" insulation, 100-ft. coil F61512	250		UL 1821 NSF-61 NSF-14	cNSFus-pw-fs
2" Pre-insulated Uponor AquaPEX with 1 1/2" insulation, 75-ft. coil	2000		NSF/ANSI/CAN 61 NSF/ANSI 14	cNSFus-pw
3/4" Pre-insulated Uponor AquaPEX with 1" insulation, 100-ft. coil	0750		UL 1821 NSF-61 NSF-14	cNSFus-pw-fs

Installation

Related applications

Approved fitting system is ProPEX®. Refer to the ProPEX Connections Instructional Guide, Uponor Piping Pocket Guide, PEX Piping Systems Design and Installation Manual (PDIM), Complete Design Assistance Manual (CDAM), Hydronic Piping Design Assistance Manual (HPDAM) or AquaSAFE<sup>TM</sup> Residential Fire Sprinkler Installation Guide for more information.

Radiant Heating and Cooling Systems

Hydronic Piping Systems

PEX-a Plumbing Systems

## Notes

Operating condition limits

(hydrostatic ratings):

1/2"-2" Uponor AquaPEX® White only: 120°F (49°C) at 130 psi (896 kPa)

Operating condition limits (hydrostatic ratings):

 $1\!\!/\!_2$ "-2" Uponor AquaPEX® White only: 120°F (49°C) at 130 psi (896 kPa)

Footnotes	Contact i	nformation
	Uponor Inc.	Uponor Ltd.
	5925 148th Street West	6510 Kennedy Road
-	Apple Valley, MN 55124	Mississauga, ON L5T 2X4
	T 800.321.4739	T 888.594.7726
	F 952.891.2008	F 800.638.9517