

# Recessed pendent sprinklers

## Project information

Job name:	Location:
Engineer:	Date submitted:
Contractor:	Submitted by:
Manufacturer's representative:	Approved by:

## Technical data

Temp/pressure ratings	73 °F (23 °C) at 160 psi (11 bar)
	180 °F (82 °C) at 100 psi (6.9 bar)
	200 °F (93 °C) at 80 psi (5.5 bar)
Prop 65 label required?	Yes



Part name	Part no.	Weight per UOM [lbs/UOM]
LF Recessed Pendent Sprinkler, 155F, 3.0 K-factor, White	LF73000WH	0.15
LF Recessed Pendent Sprinkler, 175F, 3.0 K-factor, White	LF73001WH	0.15
LF Recessed Pendent Sprinkler, 155F, 4.9 K-factor, White	LF74900WH	0.15
LF Recessed Pendent Sprinkler, 175F, 4.9 K-factor, White	LF74901WH	0.15

Installation	Related applications
-	AquaSAFE™ Fire Safety Systems

Codes	Standards	Listings
-	-	-

Footnotes	Contact information										
-	<table border="0"> <tr> <td>Uponor Inc.</td> <td>Uponor Ltd.</td> </tr> <tr> <td>5925 148th Street West</td> <td>6510 Kennedy Road</td> </tr> <tr> <td>Apple Valley, MN 55124</td> <td>Mississauga, ON L5T 2X4</td> </tr> <tr> <td>T 800.321.4739</td> <td>T 888.594.7726</td> </tr> <tr> <td>F 952.891.2008</td> <td>F 800.638.9517</td> </tr> </table>	Uponor Inc.	Uponor Ltd.	5925 148th Street West	6510 Kennedy Road	Apple Valley, MN 55124	Mississauga, ON L5T 2X4	T 800.321.4739	T 888.594.7726	F 952.891.2008	F 800.638.9517
Uponor Inc.	Uponor Ltd.										
5925 148th Street West	6510 Kennedy Road										
Apple Valley, MN 55124	Mississauga, ON L5T 2X4										
T 800.321.4739	T 888.594.7726										
F 952.891.2008	F 800.638.9517										