

ASTM WIPEX fittings

| Project information | |
|--------------------------------|-----------------|
| Job name: | Location: |
| Engineer: | Date submitted: |
| Contractor: | Submitted by: |
| Manufacturer's representative: | Approved by: |

Technical data

Temp/pressure ratings

Material Brass

Subcomponent Material Body: DZR (dezincification-resistant) brass

Clamp ring: DZR brass
Bolt: Stainless steel
Nut: Stainless steel
Washer: Stainless steel
73 °F (23 °C) at 160 psi (11 bar)
180 °F (82 °C) at 100 psi (6.9 bar)
200 °F (93 °C) at 80 psi (5.5 bar)

Prop 65 label required? Yes

Product information and application use

WIPEX™ Fittings are used for all types of Uponor's crosslinked polyethylene (PEX-a) tubing applications. Dezincification-resistant (DZR) brass fittings are safe for direct burial in soil.



| Part name | Part no. | End Type 1 | End Type 2 | A [inch] | B [inch] | C [inch] | Weight per UOM [lbs/UOM] |
|-------------------------------|----------|-------------------|------------|----------|----------|----------|--------------------------------|
| WIPEX Fitting 1" PEX x 1" NPT | 5550010 | Compression 1" | MNPT 1" | - | - | - | 0.63 |
| WIPEX Fitting 4" x 4" NPT | 5550040 | Compression 4" | MNPT 4" | 5.52 | 5.551 | 4.724 | 10 |

| Part name | Part no. | Codes | Standards | Listings |
|---------------------|----------|---------|-----------------------------|----------|
| ASTM WIPEX fittings | All | IMC UMC | CSA B137.5 NSF-14 ASTM F877 | IAPMO-ES |

| Installation | Related applications |
|--------------|----------------------|
|--------------|----------------------|

Use DZR brass adapters to transition Uponor PEX tubing to male NPT thread. Use EPDM O-rings between the different parts for sealing. For more information, refer to the Uponor WIPEX Fittings Instruction Sheet.

Pre-Insulated Pipe Systems

Radiant Heating and Cooling Systems

Permafrost Prevention Systems

Turf Conditioning Systems

| Footnotes | Contact information | | |
|-----------|------------------------|-------------------------|--|
| | Uponor Inc. | Uponor Ltd. | |
| | 5925 148th Street West | 6510 Kennedy Road | |
| | Apple Valley, MN 55124 | Mississauga, ON L5T 2X4 | |
| | T 800.321.4739 | T 888.594.7726 | |
| | F 952.891.2008 | F 800.638.9517 | |