

Quik Trak combo panels

Proje	Project information			
Job i	name:	Location:		
Engi	ineer:	Date submitted:		
Cont	tractor:	Submitted by:		
Man	ufacturer's representative:	Approved by:		

Technical data

Material Wood

Subcomponent Material 1/2" plywood with aluminum backing

Prop 65 label required? Yes

Product information and application use

Quik Trak® Panels are designed for use with 5 /16" Wirsbo hePEXTM tubing only. The $\frac{1}{2}$ -inch plywood panels come attached to an aluminum heat-transfer sheet.



Part name	Part no.	A [mm]	B [mm]	C [mm]	Weight per UOM [kg/UOM]
Quik Trak 12" x 48" Combo Panel, 6 runs with return	A5060712	1212.85	298.45	12.70	2.018
Quik Trak 12" x 12" Combo 90, 6 runs	A5060722	298.45	298.45	12.70	0.454
Quik Trak 7" x 12" Combo Access Panel, 6 runs with 1 access	A5060732	298.45	173.61	12.70	0.227

Installation Related applications

Place Quik Trak Panels on floor surface, ensuring the seams are staggered. Secure one side of the panel with a screw on each end to allow for quick realignment of panels. After properly placing the panels, secure each one with ten screws (five on each side of the groove). Clean any debris from the panel grooves. Apply a thin (?") bead of 100% silicone Quik Trak Sealant (E6050010) throughout the entire length of the groove. The silicone acts as an adhesive agent, promoting good heat transfer from the tubing to the panel. Install the tubing according to the design. For additional information, refer to the Uponor Quik Trak Installation Manual and the Uponor Radiant Floor Heating Installation Handbook

Radiant Heating and Cooling Systems
Permafrost Protection Systems
Turf Conditioning Systems

Footnotes	Contact information		
	Uponor Inc.	Uponor Ltd.	
	5925 148th Street West	6510 Kennedy Road	
•	Apple Valley, MN 55124	Mississauga, ON L5T 2X4	
	T 800.321.4739	T 888.594.7726	
	F 952.891.2008	F 800.638.9517	