

Stainless-steel manifold replacement gaskets

Project information

Job name:	Location:
Engineer:	Date submitted:
Contractor:	Submitted by:
Manufacturer's representative:	Approved by:

Technical data

Temp/pressure ratings	68 °F (20 °C) at 145 psi (10 bar)
	158 °F (70 °C) at 87 psi (6 bar)
	194 °F (90 °C) at 44 psi (3 bar)
Prop 65 label required?	Yes

Product information and application use

N/A



Installation

N/A

Related applications

-

Footnotes

-

Contact information

Uponor Inc.
5925 148th Street West
Apple Valley, MN 55124
T 800.321.4739
F 952.891.2008

Uponor Ltd.
6510 Kennedy Road
Mississauga, ON L5T 2X4
T 888.594.7726
F 800.638.9517