

Smatrix Pulse relay modules

Project information


Job name:	Location:
Engineer:	Date submitted:
Contractor:	Submitted by:
Manufacturer's representative:	Approved by:

Technical data

Operating temperature min. [°F]	32 °f
Operating temperature max. [°F]	122 °f
Ambient temperature min. [F]	-4 °f
Ambient temperature max. [F]	158 °f
Ambient humidity non-condensing max [%]	85
Prop 65 label required?	Yes

Product information and application use

The Relay Module adds two extra output relays to the Smatrix Pulse wireless control system. These can be setup in different combinations to control heating and cooling operation. The Relay Module can also be paired with a thermostat to control a fan coil or furnace and air-conditioning combination, along with fan operation. This application uses three (3) relays.



SHOWN WITHOUT POWER CABLE & RELAY ANTENNA

Part name	Part no.	A [inch]	B [inch]	C [inch]	Operating voltage AC [VAC]	Weight per UOM [lbs/UOM]
Smatrix Pulse Relay Module (M-263)	A3801263	6.693	1.969	1.102	24	0.4

Part name	Part no.	Codes	Standards	Listings
Smatrix Pulse relay modules	A3801263	-	IC RSS-210 ICC RSS-Gen FCC 47 CFR Part 15	IC 7664A-SM4NA0 FCC ID V9MSM4NA0

Installation

Related applications

Refer to the Smatrix Pulse Installation and Operation Manual for installation information.

- Radiant
- Hydronic Heating & Cooling
- Tools & Accessories

Footnotes

Contact information

-	Uponor Inc. 5925 148th Street West Apple Valley, MN 55124 T 800.321.4739 F 952.891.2008	Uponor Ltd. 6510 Kennedy Road Mississauga, ON L5T 2X4 T 888.594.7726 F 800.638.9517
---	---	---