

## Tee insulation kits

### Project Information

|                                 |                 |
|---------------------------------|-----------------|
| Job name :                      | Location :      |
| Engineer :                      | Date submitted: |
| Contractor :                    | Submitted by:   |
| Manufacturer's representative : | Approved by :   |

### Technical data

Prop 65 label required? Yes

### Product information and application use

The Tee Insulation Kit makes an insulated tee connection of single or twin-style Uponor Ecoflex® piping products with a jacket size of 5.5", 6.9" and 7.9". The kit features two shells, stainless-steel bolts, plastic pins and joint-sealing compound. Use with Uponor Ecoflex rubber end caps only.



| Part name                           | Part no. | Weight per UOM [lbs/UOM] |
|-------------------------------------|----------|--------------------------|
| Tee Insulation Kit, 5.5", 6.9", 7.9 | 1021990  | 19.4                     |

### Installation

If needed, install reducing sockets before couplings. Conduct hydraulic pressure test after installing couplings. Use Ecoflex rubber end caps (required) at all ends of the piping system to ensure insulation integrity. Refer to the Ecoflex Insulation Kits Instruction Sheet for further information.

### Related applications

Pre-Insulated Pipe Systems  
PEX-a Plumbing Systems (Canada only)

### Codes

### Standards

### Listings

### Footnotes

### Contact information

|   |  |  |
|---|--|--|
| - | <p>Uponor Inc.<br/>5925 148th Street West<br/>Apple Valley, MN 55124<br/>T 800.321.4739<br/>F 952.891.2008</p> | <p>Uponor Ltd.<br/>6510 Kennedy Road<br/>Mississauga, ON L5T 2X4<br/>T 888.594.7726<br/>F 800.636.9517</p> |
|---|--|--|