

Quik Trak combo panels

Project Information

Job name :	Location :
Engineer :	Date submitted:
Contractor :	Submitted by:
Manufacturer's representative :	Approved by :

Technical data

Material	Wood
Prop 65 label required?	Yes

Product information and application use

Quik Trak® Panels are designed for use with 5/16" Wirsbo hePEX™ tubing only. The 1/2-inch plywood panels come attached to an aluminum heat-transfer sheet.



Part name	Part no.	A [Inch]	B [Inch]	C [Inch]	Weight per UOM [lbs/UOM]
Quik Trak 12" x 48" Combo Panel, 6 runs with return	A5060712	47.75	11.75	0.5	4.45
Quik Trak 12" x 12" Combo 90, 6 runs	A5060722	11.75	11.75	0.5	1
Quik Trak 7" x 12" Combo Access Panel, 6 runs with 1 access	A5060732	11.75	6.835	0.5	0.5

Installation

Place Quik Trak Panels on floor surface, ensuring the seams are staggered. Secure one side of the panel with a screw on each end to allow for quick realignment of panels. After properly placing the panels, secure each one with ten screws (five on each side of the groove). Clean any debris from the panel grooves. Apply a thin (?) bead of 100% silicone Quik Trak Sealant (E6050010) throughout the entire length of the groove. The silicone acts as an adhesive agent, promoting good heat transfer from the tubing to the panel. Install the tubing according to the design. For additional information, refer to the Uponor Quik Trak Installation Manual and the Uponor Radiant Floor Heating Installation Handbook

Related applications

- Radiant Heating and Cooling Systems
- Permafrost Protection Systems
- Turf Conditioning Systems

Codes

Standards

Listings

-

Trademark Information

ProPEX® is a registered trademark of Uponor Inc. ProPEX™ is a trademark of Uponor Ltd.

Contact Information

Uponor Inc.
5925 148th Street West
Apple Valley, MN 55124
T 800.321.4739
F 952.891.2008

Uponor Ltd.
6510 Kennedy Road
Mississauga, ON L5T 2X4
T 888.594.7726
F 800.636.9517