

## PEX clips

| Project information            |                 |
|--------------------------------|-----------------|
| Job name:                      | Location:       |
| Engineer:                      | Date submitted: |
| Contractor:                    | Submitted by:   |
| Manufacturer's representative: | Approved by:    |

## Technical data

Material Plastic
Subcomponent Material Nylon

Product information and application use

Uponor PEX Clips are designed to suspend crosslinked polyethylene (PEX) tubing below the underside of a subfloor in a joist cavity installation.





| Part name               | Part no. | A [mm] | B [mm] | C [mm] | Prop 65 label required? | Weight per<br>UOM<br>[kg/UOM] |
|-------------------------|----------|--------|--------|--------|-------------------------|-------------------------------|
| 3/8" PEX Clip, 100/pkg. | F7060375 | 17.40  | 28.95  | 40.97  | -                       | 0.0068038936                  |
| 1/2" PEX Clip, 100/pkg. | F7051258 | 17.40  | 28.95  | 42.56  | -                       | 0.0072574866                  |
| 3/4" PEX Clip, 100/pkg. | F7057500 | 17.40  | 35.20  | 48.56  | No                      | 0.0081646724                  |
| 1" PEX Clip, 50/pkg.    | F7051001 | 17.40  | 44.95  | 55.93  | No                      | 0.013                         |

Installation Related applications

Mount the PEX Clips to the underside of the subfloor in the joist cavity with the use of a drywall screw or nail. Secure the tubing to the clips at 36" intervals along the joist cavity. Refer to the Uponor Radiant Installation Handbook for additional information.

Radiant Heating and Cooling Systems

| Footnotes | Contact ii             | Contact information     |  |  |
|-----------|------------------------|-------------------------|--|--|
|           | Uponor Inc.            | Uponor Ltd.             |  |  |
|           | 5925 148th Street West | 6510 Kennedy Road       |  |  |
| -         | Apple Valley, MN 55124 | Mississauga, ON L5T 2X4 |  |  |
|           | T 800.321.4739         | T 888.594.7726          |  |  |
|           | F 952.891.2008         | F 800.638.9517          |  |  |