# Copper valved manifolds with ProPEX ball and balancing valves



Project information	
Job name:	Location:
Engineer:	Date submitted:
Contractor:	Submitted by:
Manufacturer's representative:	Approved by:

### Technical data

Material Copper Manifold size 2 inch

Temp/pressure ratings 73 °F (23 °C) at 160 psi (11 bar) 180 °F (82 °C) at 100 psi (6.9 bar) 200 °F (93 °C) at 80 psi (5.5 bar)

200 °F (93 °C) at 80 psi (5.5 bar) 210 °F (99 °C) at 149 psi (10.3 bar)

Max. fluid flow rate 45 gpm Prop 65 label required? Yes

## Product information and application use

Uponor offers 2" Copper Valved Manifold with ProPEX® Ball and Balancing Valves for radiant heating projects.1 The manifold has a 2" Copper Sweat Fitting Adapter supply connection and  $\frac{3}{4}$ " nominal branches. This 12-outlet manifold is preassembled with  $\frac{5}{8}$ " or  $\frac{3}{4}$ " ProPEX balancing valve connections.



Part name	Part no.	A [mm]	B [mm]	C [mm]	Cv Branch	End Type 1	Weight per UOM [kg/UOM]
2" x 4' Copper Valved Manifold with 5/8" ProPEX Ball and Balancing Valves, 12 outlets	Q2821263	1219.20	197.87	66.87	6.6	ProPEX 5/8"	6.9173
2" x 4' Copper Valved Manifold with 3/4" ProPEX Ball and Balancing Valves, 12 outlets	Q2821275	1219.20	199.92	66.87	6.7	ProPEX 3/4"	6.9173

Part name	Part no.	Codes	Standards	Listings
Copper valved manifolds with ProPEX ball and balancing valves	All	-	CSA B137.5 ASTM F877	cNSFus-rfh

## Installation Related applications

Install using any product designed to mount 2" copper pipe as a mounting bracket. Refer to the Uponor Radiant Floor Heating Installation Handbook for additional information.

Radiant Heating and Cooling Systems Permafrost Protection Systems

Turf Conditioning Systems

### Notes

Ball Valve Cv " outlet: 6.60 Ball Valve Cv ¾" outlet: 6.70

Footnotes	Contact information		
	Uponor Inc.	Uponor Ltd.	
	5925 148th Street West	6510 Kennedy Road	
•	Apple Valley, MN 55124	Mississauga, ON L5T 2X4	
	T 800.321.4739	T 888.594.7726	
	F 952.891.2008	F 800.638.9517	