


EP heating manifolds

Project information	
Job name:	Location:
Engineer:	Date submitted:
Contractor:	Submitted by:
Manufacturer's representative:	Approved by:

Technical data

Material Engineered Polymer Subcomponent Material Manifold: PA66-GF30 Valve Insert, Handwheels: POM Metal Inserts: Brass C38500 Axel: Stainless Steel Spring: Stainless Steel O-ring: EPDM Loop Cv 1.4 Cv End type 1 ISO 228-G 1-1/4" End type 2 ISO 228-G 3/4" 140 °F (60 °C) at 87 psi (6 bar) Temp/pressure ratings 158 °F (70 °C) at 72 psi (5 bar) 176 °F (80 °C) at 58 psi (4 bar) 194 °F (90 °C) at 44 psi (3 bar) Max. fluid flow rate 15.4 gpm Prop 65 label required? Yes





Product information and application use

The Engineered Polymer (EP) Heating Manifold Assemblies feature isolation valves and balancing valves with flow meters (0-1 gpm), and come fully assembled, ready for installation in hydronic radiant heating and cooling systems. The body ends feature R32 unions and the loop outlets have R20 male threads. Use only propylene glycol in radiant systems with EP Heating Manifolds; never use ethylene glycol.

Installation Related applications

Do not use thread sealant on connections. Carriers present in these compounds can crack the plastic port connections, resulting in leaks and water damage. For additional information, refer to the EP Heating Manifold Instruction Sheet. Note: Use only propylene glycol in radiant heating and cooling systems with EP Heating Manifolds; never use ethylene glycol. Refer to the EP Heating Manifold Installation Guide for a complete chemicals list.

Radiant Heating and Cooling Systems

Permafrost Protection Systems

Turf Conditioning Systems

Notes

Compatible Actuators:

A3023522 Thermal Actuator, four-wire; A3030522 Two-wire Thermal Actuator for EP Heating Manifolds

Footnotes	Contact information	
	Uponor Inc.	Uponor Ltd.
	5925 148th Street West	6510 Kennedy Road
•	Apple Valley, MN 55124	Mississauga, ON L5T 2X4
	T 800.321.4739	T 888.594.7726
	F 952.891.2008	F 800.638.9517