υροποι

Stainless-steel manifold replacement gaskets

Project information			
Job name:		Location:	
Engineer:		Date submitted:	
Contractor:		Submitted by:	
Manufacturer's representative:		Approved by:	
Technical data			
Temp/pressure ratings Prop 65 label required?	68 °F (20 °C) at 145 psi (10 bar) 158 °F (70 °C) at 87 psi (6 bar) 194 °F (90 °C) at 44 psi (3 bar) Yes		
Product information and ap	plication use		
(Replacement part) Stainle: connections.	ss-steel manifold replacement gaskets are for use with R32 union		

Part name	Part no.	A [inch]	B [inch]	Weight per UOM [ibs/UOM]
Stainless-steel Manifold Replacement Gasket for R32 Union Connection	A2771040	1.53	0.098	0
Installation		Related applications		
N/A		Radiant heating systems		

Footnotes	Contact i	Contact information	
	Uponor Inc.	Uponor Ltd.	
	5925 148th Street West	6510 Kennedy Road	
	Apple Valley, MN 55124	Mississauga, ON L5T 2X4	
	T 800.321.4739	T 888.594.7726	
	F 952.891.2008	F 800.638.9517	