

PEX clips

Project information

| | |
|--------------------------------|-----------------|
| Job name: | Location: |
| Engineer: | Date submitted: |
| Contractor: | Submitted by: |
| Manufacturer's representative: | Approved by: |

Technical data

| | |
|-----------------------|---------|
| Material | Plastic |
| Subcomponent Material | Nylon |

Product information and application use

Uponor PEX Clips are designed to suspend crosslinked polyethylene (PEX) tubing below the underside of a subfloor in a joist cavity installation.



| Part name | Part no. | A [inch] | B [inch] | C [inch] | Prop 65 label required? | Weight per UOM [lbs/UOM] |
|-------------------------|----------|----------|----------|----------|-------------------------|--------------------------|
| 3/8" PEX Clip, 100/pkg. | F7060375 | 0.685 | 1.14 | 1.613 | - | 0.015 |
| 1/2" PEX Clip, 100/pkg. | F7051258 | 0.685 | 1.14 | 1.676 | - | 0.016 |
| 3/4" PEX Clip, 100/pkg. | F7057500 | 0.685 | 1.386 | 1.912 | Yes | 0.018 |
| 1" PEX Clip, 50/pkg. | F7051001 | 0.685 | 1.77 | 2.202 | Yes | 0.03 |

| Installation | Related applications |
|---|-------------------------------------|
| Mount the PEX Clips to the underside of the subfloor in the joist cavity with the use of a drywall screw or nail. Secure the tubing to the clips at 36" intervals along the joist cavity. Refer to the Uponor Radiant Installation Handbook for additional information. | Radiant Heating and Cooling Systems |

| Footnotes | Contact information |
|-----------|---|
| - | <div>Uponor Inc. 5925 148th Street West Apple Valley, MN 55124 T 800.321.4739 F 952.891.2008</div> <div>Uponor Ltd. 6510 Kennedy Road Mississauga, ON L5T 2X4 T 888.594.7726 F 800.638.9517</div> |