υροποι


Uponor PP-RCT crossovers (molded)

| Project information | | |
|--------------------------------|-----------------|--|
| Job name: | Location: | |
| Engineer: | Date submitted: | |
| Contractor: | Submitted by: | |
| Manufacturer's representative: | Approved by: | |
| Technical data | | |

| roomilour data | |
|-----------------------|--------------------------------------|
| Material | PP-RCT |
| Temp/pressure ratings | 73 °F (23 °C) at 340 psi (23.44 bar) |
| | 140 °F (60 °C) at 190 psi (13.1 bar) |
| | 180 °F (82 °C) at 100 psi (6.9 bar) |
| | |

Product information and application use

Use Uponor PP-RCT crossovers with Uponor PP-RCT mechanical pipe to convey water for hydronic heating and cooling or industrial applications.



| Part name | Part no. | End Type 1 | End Type 2 |
|---|-----------|-------------|-------------|
| Uponor PP-RCT Crossover, Molded, 1" x 1 | PR4481010 | Socket 1" | Socket 1" |
| Uponor PP-RCT Crossover, Molded, 1/2" x 1/2 | PR4485050 | Socket 1/2" | Socket 1/2" |
| Uponor PP-RCT Crossover, Molded, 3/4" x 3/4 | PR4487575 | Socket 3/4" | Socket 3/4" |

| Part name | Part no. | Codes | Standards | Listings |
|-----------------------------------|----------|-------------|--------------------------------|-------------------------------|
| | All | CMCIIMCIUMC | ASTM E84 NSF-14 ASTM F2389 CSA | ICC-ES-PMG 1106 IAPMO-R&T |
| Uponor PP-RCT crossovers (molded) | | | B137.11 | 8358 QAI P321-5 IAPMO K-12775 |

| Installation | Related applications |
|--|--|
| Use approved butt-fusion connection methods. Refer to the Uponor PP-RCT manual for complete details. | Hydronic heating and cooling systems Industrial |

| Footnotes | Contact information | | |
|-----------|------------------------|-------------------------|--|
| | Uponor Inc. | Uponor Ltd. | |
| | 5925 148th Street West | 6510 Kennedy Road | |
| | Apple Valley, MN 55124 | Mississauga, ON L5T 2X4 | |
| | T 800.321.4739 | T 888.594.7726 | |
| | F 952.891.2008 | F 800.638.9517 | |