υροποι

Uponor PP-RCT brass unions (socket fusion)

Project information			
Job name:		Location:	
Engineer:		Date submitted:	
Contractor:		Submitted by:	
Manufacturer's representativ	/e:	Approved by:	
Technical data			
Material Temp/pressure ratings	PP-RCT 73 °F (23 °C) at 340 psi (23.44 bar) 140 °F (60 °C) at 190 psi (13.1 bar) 180 °F (82 °C) at 100 psi (6.9 bar)		
Product information and application use			
Use Uponor PP-RCT brass unions with Uponor PP-RCT mechanical pipe to convey water for hydronic heating and cooling or industrial applications.			

BRASS UNION (FOR SOCKET FUSION)

Part name	Part no.	End Type 1	End Type 2	Prop 65 label required?
Uponor PP-RCT Brass Union, 1/2	PR4720500	Socket 1/2"	Socket 1/2"	Yes
Uponor PP-RCT Brass Union, 3/4	PR4720750	Socket 3/4"	Socket 3/4"	Yes
Uponor PP-RCT Brass Union, 1	PR4721000	Socket 1"	Socket 1"	Yes
Uponor PP-RCT Brass Union, 1 1/4	PR4721250	Socket 1-1/4"	Socket 1-1/4"	Yes
Uponor PP-RCT Brass Union, 1 1/2	PR4721500	Socket 1-1/2"	Socket 1-1/2"	Yes
Uponor PP-RCT Brass Union, 2	PR4722000	Socket 2"	Socket 2"	No

Part name	Part no.	Codes	Standards	Listings
Uponor PP-RCT brass unions (socket fusion)	All	CMCIIMCIUMC	ASTM E84 NSF-14 ASTM F2389 CSA B137.11	ICC-ES-PMG 1106 IAPMO-R&T 8358 QAI P321-5 IAPMO K-12775

Installation	Related applications
Use approved socket-fusion connection methods. Refer to the Uponor PP-RCT manual for complete	Hydronic heating and c
details	

Hydronic heating and cooling systems

Industrial	
------------	--

Contact In	formation
Uponor Inc.	Uponor Ltd.
5925 148th Street West	6510 Kennedy Road
Apple Valley, MN 55124	Mississauga, ON L5T 2X4
T 800.321.4739	T 888.594.7726
F 952.891.2008	F 800.638.9517
	Uponor Inc. 5925 148th Street West Apple Valley, MN 55124 T 800.321.4739