

Uponor PP-RCT 45 elbows, hot potable (butt fusion)

Project information	
Job name:	Location:
Engineer:	Date submitted:
Contractor:	Submitted by:
Manufacturer's representative:	Approved by:

Technical data


Material PP-RCT

Temp/pressure ratings 73 °F (23 °C) at 265 psi (18.27 bar) 140 °F (60 °C) at 150 psi (10.34 bar) 180 °F (82 °C) at 100 psi (6.9 bar)

Product information and application use

Use Uponor PP-RCT hot potable pipe to convey water for hot potable plumbing applications. The fiber layer coextruded into the mid-wall of the pipe to reduce expansion/contraction with temperature changes also makes the pipe acceptable for use in hydronic heating and cooling applications.

Note: Temperature and pressure ratings stated are hydrostatic ratings. For domestic hot-water (DHW) and DHW recirculation installations, operating conditions should not exceed 140°F (60°C) at 80 psi (5.5 bar) in accordance with ASTM F2023. For additional information regarding application-specific temperature and pressure ratings, refer to the Uponor PP-RCT Piping Systems Manual, the Uponor PP-RCT Piping Systems Installation Guide, and the Uponor PP-RCT DHW Systems Design, Installation, and Operation Guidelines.



P	Part name	Part no.	A [inch]	B [inch]	C [inch]	D [inch]	E [inch]	Equivalent length through [ft]	End Type 1	End Type 2	Weight per UOM [lbs/UOM]
L	Jponor PP-RCT 45 Elbow, Hot Potable, 6" x 6", SDR 9	PR94764560	19.756	12.638	6.299	0.7	-	6	Butt 6"	Butt 6"	8.43
U	Jponor PP-RCT 45 Elbow, Hot Potable, 8" x 8", SDR 9	PR94764580	33.606	19.493	7.874	0.876	-	7.6	Butt 8"	Butt 8"	23.38

Part name	Part no.	Codes	Standards	Listings		
Uponor PP-RCT 45 elbows, hot potable (butt fusion)	All	UPC IRC IPC NPC of Canada UMC CMC CPC IMC	NSF/ANSI/CAN 61 ASTM E84 NSF/ANSI 14 ASTM F2389 CSA B137.11	ICC-ES-PMG 1106 IAPMO-R&T 8358 QAI P321-5 IAPMO K-12775		

Installation Related applications

Use approved butt-fusion connection methods. Refer to the Uponor PP-RCT manual for complete

Note: Temperature and pressure ratings stated are hydrostatic ratings. For domestic hot-water (DHW) and DHW recirculation installations, operating conditions should not exceed 140°F (60°C) at 80 psi (5.5 bar) in accordance with ASTM F2023. For additional information regarding application-specific temperature and pressure ratings, refer to the Uponor PP-RCT Piping Systems Manual, the Uponor PP-RCT Piping Systems Installation Guide, and the Uponor PP-RCT DHW Systems Design, Installation, and Operation Guidelines.

Domestic water systems

Hydronic heating and cooling systems

	Footnotes	Contact in	Contact information		
		Uponor Inc.	Uponor Ltd.		
		5925 148th Street West	6510 Kennedy Road		
-		Apple Valley, MN 55124	Mississauga, ON L5T 2X4		
		T 800.321.4739	T 888.594.7726		
		F 952.891.2008	F 800.638.9517		