

# EP heating manifold end caps with vent and drain

## Project information

|                                |                 |
|--------------------------------|-----------------|
| Job name:                      | Location:       |
| Engineer:                      | Date submitted: |
| Contractor:                    | Submitted by:   |
| Manufacturer's representative: | Approved by:    |

## Product information and application use

The Engineered Plastic (EP) Heating Manifold End Cap with Vent and Drain (A2671250) allows filling and purging at the EP Heating Manifold for use in hydronic radiant heating and cooling systems. Only use propylene glycol in radiant systems with EP Heating Manifolds; never use methanol or ethylene glycol.



## Installation

Hand-tighten the end cap to the manifold. For additional information, refer to the instruction sheet.  
 Note: Use only propylene glycol in radiant heating and cooling systems with EP Heating Manifolds; never use methanol or ethylene glycol. Refer to the EP Heating Manifold Installation Guide for a complete chemical compatibility list.

## Related applications

- Radiant Heating and Cooling Systems
- Permafrost Protection Systems
- Turf Conditioning Systems

## Footnotes

## Contact information

Uponor Inc.  
 5925 148th Street West  
 Apple Valley, MN 55124  
 T 800.321.4739  
 F 952.891.2008

Uponor Ltd.  
 6510 Kennedy Road  
 Mississauga, ON L5T 2X4  
 T 888.594.7726  
 F 800.638.9517