

TruFLOW manifold loop temperature gauges

Project information

Job name:	Location:
Engineer:	Date submitted:
Contractor:	Submitted by:
Manufacturer's representative:	Approved by:

Technical data

Material	Brass
Temp/pressure ratings	73 °F (23 °C) at 160 psi (11 bar) 180 °F (82 °C) at 100 psi (6.9 bar) 200 °F (93 °C) at 80 psi (5.5 bar)
Prop 65 label required?	Yes

Product information and application use

TruFLOW™ Manifold Loop Temperature Gauge comes with a QS20 female union on one end and a QS20 male on the other end. Part includes temperature gauge well and removable temperature gauge.



Part name	Part no.	End Type 1
TruFLOW Manifold Loop Temperature Gauge	A2610020	ISO 228-G
Temperature Gauge with Well, replacement part	A2610120	-

Part name	Part no.	Codes	Standards	Listings
TruFLOW manifold loop temperature gauges	All	-	ASTM F877 R20: ISO 228-G ¾"	-

Installation

Install the TruFLOW Manifold Loop Temperature Gauge Nipple on the R20 loop outlet on the return side of the TruFLOW Manifold assembly. Install the desired fitting assembly on the outlet of the TruFLOW Manifold Loop Temperature Gauge Nipple. Use only TruFLOW Manifolds. Accessories: Temperature Gauge with Well, replacement part (A2610120). Refer to the Uponor Radiant Installation Handbook for additional information.

Related applications

Radiant Heating and Cooling Systems

Notes

Connection:  
R20 QS-style

Footnotes	Contact information
-	Uponor Inc. 5925 148th Street West Apple Valley, MN 55124 T 800.321.4739 F 952.891.2008 Uponor Ltd. 6510 Kennedy Road Mississauga, ON L5T 2X4 T 888.594.7726 F 800.638.9517