## υροποι


### TotalFit reducing tees


Project information	
Job name:	Location:
Engineer:	Date submitted:
Contractor:	Submitted by:
Manufacturer's representative:	Approved by:

# Technical data Engineered Polymer Temp/pressure ratings 73 °F (23 °C) at 160 psi (11 bar) 180 °F (82 °C) at 100 psi (6.9 bar) 200 °F (93 °C) at 80 psi (5.5 bar) Prop 65 label required? No

#### Product information and application use

TotalFit<sup>™</sup> is the professional-grade engineered polymer (EP) push-to-connect solution that provides greater value for residential projects with the same versatility and speed as brass push-to-connect fittings for PEX, PE-RT, CPVC, and copper piping systems.





Part name	Part no.	End Type 1	End Type 2	End Type 3
TotalFit Reducing Tee, 1" x 1" x 1/2	TF4751150	TotalFit 1"	TotalFit 1"	TotalFit 1/2"
TotalFit Reducing Tee, 1" x 1" x 3/4	TF4751175	TotalFit 1"	TotalFit 1"	TotalFit 3/4"
TotalFit Reducing Tee, 3/4" x 3/4" x 1/2	TF4757550	TotalFit 3/4"	TotalFit 3/4"	TotalFit 1/2"
TotalFit Reducing Tee, 3/4" x 1/2" x 1/2	TF4757555	TotalFit 3/4"	TotalFit 1/2"	TotalFit 1/2"

Part name	Part no.	Codes	Standards	Listings	
TotalFit reducing tees	All	UPC IRC IPC NPC of Canada UMC CMC CPC IMC	ASTM F877 NSF/ANSI/CAN 372 NSF/ANSI/CAN 61 NSF/ANSI 14 ASSE 1061	IAPMO K-13573 IAPMO K- 13571 IAPMO K-13572	
In addition, the following parts have additional codes, standards, or listings:					
TotalFit Reducing Tee, 1" x 1" x 3/4	TF4751175				

#### Installation

Install on PEX, PE-RT, CPVC, and copper piping systems. Use deburr and depth tool to remove excess material or burrs and mark the appropriate depth on pipe. If using flexible PEX or PE-RT, install the insert inside the pipe first before making the connection. Refer to the Uponor TotalFit Instruction Sheet for additional information.

#### **Related applications**

Plumbing

Hydronic Heating & Cooling

Uponor Inc.	Uponor Ltd.
5925 148th Street West	6510 Kennedy Road
Apple Valley, MN 55124	Mississauga, ON L5T 2X4
T 800.321.4739	T 888.594.7726
F 952.891.2008	F 800.638.9517
	5925 148th Street West Apple Valley, MN 55124 T 800.321.4739