
Uponor

Smatrix Pulse expansion modules

Project information	
Job name:	Location:
Engineer:	Date submitted:
Contractor:	Submitted by:
Manufacturer's representative:	Approved by:

l echnical data		
Operating temperature min. [°F]	32 °f	
Operating temperature max. [°F]	113 °f	
Ambient temperature min. [F]	-4 °f	
Ambient temperature max. [F]	158 °f	
Ambient humidity non-condensing max [%]	85	
Prop 65 label required?	Yes	
Product information and application use		
The Smatrix Pulse Expansion Module (M-262) increases the Smatrix Pulse Controller (X-265) capacity with six (6) additional thermostats along with six (6) more actuators. The Expansion Module operates the actuators, which, in turn, affect the flow of the supply water to change the indoor		

temperature using information transmitted from registered thermostats and system parameters.





Part name	Part no.	A [inch]	B [inch]	C [inch]	D [inch]	Operating voltage AC [VAC]	Weight per UOM [lbs/UOM]
Smatrix Pulse Expansion Module (M-262)	A3801262	6.417	4.331	2.165	5.551	115	0.61
Installation Related applications							
Radiant							
Refer to the Smatrix Pulse Installation and Operation Manual for installation information.			Hydronic Heating & Cooling				

Tools & Accessories

Footnotes	Contact i	Contact information			
	Uponor Inc.	Uponor Ltd.			
	5925 148th Street West	6510 Kennedy Road			
	Apple Valley, MN 55124	Mississauga, ON L5T 2X4			
	T 800.321.4739	T 888.594.7726			
	F 952.891.2008	F 800.638.9517			