

# Smatrix Pulse transformer, replacement parts

## Project Information


Job name:	Location:
Engineer:	Date submitted:
Contractor:	Submitted by:
Manufacturer's representative:	Approved by:

## Technical data

Operating temperature min. [°F]	32 °f
Operating temperature max. [°F]	113 °f
Ambient temperature min. [F]	-4 °f
Ambient temperature max. [F]	158 °f
Ambient humidity non-condensing max [%]	85
Prop 65 label required?	Yes

## Product Information and application use

The Smatrix Pulse Transformer replacement part replaces the transformer in both the A380265C Smatrix Pulse Controller (X-265) with Communication Module (R-208) and the A380265A Smatrix Pulse Controller (X-265) with Antenna (A-265). The transformer is the power supply for the Smatrix Pulse wireless control system.



POWER CABLES NOT SHOWN

Part name	Part no.	Codes	Standards	Listings
Smatrix Pulse transformer, replacement parts	A3850050	-	UL 506 CAN/CSA C22.2 No. 66.2 UL 5085-2 CAN/CSA C22.2 No. 66.1 UL 5085-1	UL E527767

## Installation

Refer to the Smatrix Pulse Installation and Operation Manual for installation information.

## Related applications

- Radiant
- Hydronic Heating & Cooling
- Tools & Accessories

## Footnotes

-

## Contact information

Uponor Inc.  
5925 148th Street West  
Apple Valley, MN 55124  
T 800.321.4739  
F 952.891.2008

Uponor Ltd.  
6510 Kennedy Road  
Mississauga, ON L5T 2X4  
T 888.594.7726  
F 800.638.9517