

## **Smatrix Pulse mini sensors**

Project information	
Job name:	Location:
Engineer:	Date submitted:
Contractor:	Submitted by:
Manufacturer's representative:	Approved by:


## Technical data

Operating temperature min. [°F] 32 °f
Operating temperature max. [°F] 122 °f
Ambient temperature min. [F] -4 °f
Ambient temperature max. [F] 158 °f
Ambient humidity non-condensing max [%] 85
Type of battery CR2032 / 3V
Prop 65 label required? Yes

Smatrix Pulse provides precise wireless control of radiant floor heating as well as forced-air heating

Smatrix Pulse provides precise wireless control of radiant floor heating as well as forced-air heating and cooling systems in one solution that connects to a smart home assistant and can also be controlled remotely via the Smatrix Pulse App.

The Smatrix Pulse Mini Sensor (T-161) is an operative temperature sensor that provides precise measurement of thermal comfort in an inconspicuous, discreet package. The Mini Sensor connects via wireless technology to the Smatrix Pulse Controller (X-265). The controller can connect up to six (6) thermostats (or mini sensors) and eight (8) actuators. The controller operates the actuators, which, in turn, affect the flow of the supply water to change the indoor temperature using information transmitted from the registered thermostats and system parameters.



Part name	Part no.	A [inch]	B [inch]	C [inch]	Weight per UOM [lbs/UOM]
Smatrix Pulse Mini Sensor	(T-161) A380016	2.193	2.193	0.382	0.06

Part name	Part no.	Codes	Standards	Listings
Smatrix Pulse mini sensors A380	A3800161		IC RSS-210 ICC RSS-Gen FCC 47	IC 7664A-SM4NA0 FCC ID
	A3600161	-	CFR Part 15	V9MSM4NA0

Installation	Related applications
	Radiant
Refer to the Smatrix Pulse Installation and Operation Manual for installation information.	Hydronic Heating & Cooling
	Tools & Accessories

Footnotes	Contact in	Contact information		
	Uponor Inc.	Uponor Ltd.		
	5925 148th Street West	6510 Kennedy Road		
	Apple Valley, MN 55124	Mississauga, ON L5T 2X4		
	T 800.321.4739	T 888.594.7726		
	F 952.891.2008	F 800.638.9517		