

Uponor PP-RCT reducing tees, hot potable (butt fusion)

| Project information | |
|--------------------------------|-----------------|
| Job name: | Location: |
| Engineer: | Date submitted: |
| Contractor: | Submitted by: |
| Manufacturer's representative: | Approved by: |


Technical data

Temp/pressure ratings 73 °F (23 °C) at 265 psi (18.27 bar) 140 °F (60 °C) at 150 psi (10.34 bar) 180 °F (82 °C) at 100 psi (6.9 bar)

Product information and application use

Use Uponor PP-RCT hot potable pipe to convey water for hot potable plumbing applications. The fiber layer coextruded into the mid-wall of the pipe to reduce expansion/contraction with temperature changes also makes the pipe acceptable for use in hydronic heating and cooling applications.

Note: Temperature and pressure ratings stated are hydrostatic ratings. For domestic hot-water (DHW) and DHW recirculation installations, operating conditions should not exceed 140°F (60°C) at 80 psi (5.5 bar) in accordance with ASTM F2023. For additional information regarding application-specific temperature and pressure ratings, refer to the Uponor PP-RCT Piping Systems Manual, the Uponor PP-RCT Piping Systems Installation Guide, and the Uponor PP-RCT DHW Systems Design, Installation, and Operation Guidelines.



| Part name | Part no. | A [inch] | B [inch] | C [inch] | D [inch] | E [inch] | F [inch] | G [inch] | H [inch] | Equivalent length branch [ft] | Equivalent length through [ft] |
|---|------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------------------------------|---|
| Uponor PP-RCT Reducing Tee, Hot Potable, 6" x 6" x 4", SDR 9 | PR94756640 | 11.811 | 11.811 | 12.598 | 15.748 | 23.622 | 18.898 | 6.299 | 4.921 | 20.1 | 5 |
| Uponor PP-RCT Reducing Tee, Hot Potable, 8" x 8" x 4", SDR 9 | PR94758840 | 13.78 | 13.78 | 16.063 | 20 | 27.559 | 23.937 | 7.874 | 4.921 | 20.1 | 6.2 |
| Uponor PP-RCT Reducing Tee, Hot Potable, 8" x 8" x 6", SDR 9 | PR94758860 | 13.78 | 13.78 | 17.638 | 21.575 | 27.559 | 25.512 | 7.874 | 6.299 | 23.9 | 6.2 |

| Part name | Part no. | End Type 1 | End Type 2 | End Type 3 | Material group | Weight per UOM [lbs/UOM] |
|--|------------|------------|------------|------------|----------------|--------------------------------|
| Uponor PP-RCT Reducing Tee, Hot Potable, 6" x 6" x 4", SDR 9 | PR94756640 | Butt 6" | Butt 6" | Butt 4" | - | 15.31 |
| Uponor PP-RCT Reducing Tee, Hot Potable, 8" x 8" x 4", SDR | PR94758840 | Butt 8" | Butt 8" | Butt 4" | PP-RCT | 28.74 |
| Uponor PP-RCT Reducing Tee, Hot Potable, 8" x 8" x 6", SDR 9 | PR94758860 | Butt 8" | Butt 8" | Butt 6" | PP-RCT | 29.73 |

| Part name | Part no. | Codes | Standards | Listings |
|--|----------|---|---|--|
| Uponor PP-RCT reducing tees, hot potable (butt fusion) | All | UPC IRC IPC NPC of Canada UMC CMC CPC IMC | NSF/ANSI/CAN 61 ASTM E84 NSF/ANSI 14 NSF/ANSI 51 ASTM F2389 CSA B137.11 | ICC-ES-PMG 1106 IAPMO-R&T 8358 QAI P321-5 IAPMO K-12775 |

Installation Related applications

Use approved butt-fusion connection methods. Refer to the Uponor PP-RCT manual for complete details.

Note: Temperature and pressure ratings stated are hydrostatic ratings. For domestic hot-water (DHW) and DHW recirculation installations, operating conditions should not exceed 140°F (60°C) at 80 psi (5.5 bar) in accordance with ASTM F2023. For additional information regarding application-specific temperature and pressure ratings, refer to the Uponor PP-RCT Piping Systems Manual, the Uponor PP-RCT Piping Systems Installation Guide, and the Uponor PP-RCT DHW Systems Design, Installation, and Operation Guidelines.

Domestic water systems

Hydronic heating and cooling systems

| Footnotes | Contact information | | |
|-----------|------------------------|-------------------------|--|
| | Uponor Inc. | Uponor Ltd. | |
| | 5925 148th Street West | 6510 Kennedy Road | |
| • | Apple Valley, MN 55124 | Mississauga, ON L5T 2X4 | |
| | T 800.321.4739 | T 888.594.7726 | |
| | F 952.891.2008 | F 800.638.9517 | |