

90-degree plastic bend supports


| Project information | |
|--------------------------------|-----------------|
| Job name: | Location: |
| Engineer: | Date submitted: |
| Contractor: | Submitted by: |
| Manufacturer's representative: | Approved by: |

Technical data

Material Plastic

Product information and application use

Plastic Bend Support (glass-reinforced nylon) provides rigid 90-degree bend and sleeve for $\frac{3}{8}$ ", $\frac{1}{2}$ " and $\frac{3}{4}$ " Uponor PEX tubing.



| Part name | Part no. | A [inch] | B [inch] | C [inch] | D [inch] | E [inch] | F [inch] | Subcomponent Material | Weight per UOM [lbs/UOM] |
|---|--------------|-------------|-------------|-------------|-------------|-------------|-------------|--------------------------|--------------------------------|
| 3/8" Plastic Bend Support | A515037 5 | 3.866 | 4.071 | 1.025 | 3.448 | 2.475 | 1.025 | Glass-reinforced nylon | 0.05 |
| 1/2" Plastic Bend Support | A525050 0 | 3.644 | 3.646 | 0.52 | 3.125 | 2.385 | 0.52 | Glass-reinforced nylon | 0.05 |
| 3/4" Plastic Bend Support | A515075 0 | 6.109 | 6.11 | 1.225 | 5.517 | 3.84 | 1.185 | Glass-reinforced nylon | 0.15 |
| 1/2" Plastic Bend Support (not for use with Wall Support Bracket A5750500) | A515050 0 | 4.062 | 4.062 | 0.99 | 3.5 | 2.341 | 0.99 | - | 0.05 |

Installation Related applications

Snap the tubing into the Bend Support at the beginning of the bend. Continue the bend through the support and snap the tubing into the support at the end of the bend as well. Refer to the Uponor PEX Piping Systems Design and Installation Manual for additional information.

PEX-a Plumbing Systems

AquaSAFE™ Fire Safety Systems

Hydronic Distribution Systems

Radiant Heating and Cooling Systems

| Footnotes | C | Contact information | | | |
|-----------|------------------------|-------------------------|--|--|--|
| | Uponor Inc. | Uponor Ltd. | | | |
| | 5925 148th Street West | 6510 Kennedy Road | | | |
| - | Apple Valley, MN 55124 | Mississauga, ON L5T 2X4 | | | |
| | T 800.321.4739 | T 888.594.7726 | | | |
| | F 952.891.2008 | F 800.638.9517 | | | |