υροποι

Elbow insulation kits

| Project Information | | |
|--------------------------------|-----------------|--|
| Job name: | Location: | |
| Engineer: | Date submitted: | |
| Contractor: | Submitted by: | |
| Manufacturer's representative: | Approved by: | |
| | | |

Technical data

Prop 65 label required? Yes

Product information and application use

Elbow insulation kits make an insulated elbow connection of single or twin-style Uponor Ecoflex® products with a jacket size of 5.5" (140 mm), 6.9" (175 mm) and 7.9" (200 mm). The kit features two shells, stainless steel bolts, plastic pins and joint-sealing compound. Use only with Uponor rubber end caps.



| Part name | Part no. | A [inch] | B [inch] | C [inch] | Weight per UOM [lbs/UOM] |
|---|----------|--|----------|----------|-----------------------------|
| Elbow Insulation Kit, 5.5", 6.9", 7.9 | 1021991 | 29.063 | 28.875 | 4.34 | 15.2 |
| Installation | | Related applications | | | |
| If needed, install reducing sockets before couplings. Conduct hydraulic pressure test after installing couplings. Use Ecoflex rubber end caps (required) at all ends of the piping system to ensure insulation integrity. Refer to the Ecoflex Insulation Kits Instruction Sheet for further information. | | Pre-Insulated Pipe Systems PEX-a Plumbing Systems (Canada only) | | | |

| Footnotes | Contact information | | |
|-----------|------------------------|-------------------------|--|
| | Uponor Inc. | Uponor Ltd. | |
| | 5925 148th Street West | 6510 Kennedy Road | |
| | Apple Valley, MN 55124 | Mississauga, ON L5T 2X4 | |
| | T 800.321.4739 | T 888.594.7726 | |
| | F 952.891.2008 | F 800.638.9517 | |