

Horizontal sidewall sprinklers

Project information

| | |
|--------------------------------|-----------------|
| Job name: | Location: |
| Engineer: | Date submitted: |
| Contractor: | Submitted by: |
| Manufacturer's representative: | Approved by: |

Technical data

| | |
|-------------------------|-------------------------------------|
| Temp/pressure ratings | 73 °F (23 °C) at 160 psi (11 bar) |
| | 180 °F (82 °C) at 100 psi (6.9 bar) |
| | 200 °F (93 °C) at 80 psi (5.5 bar) |
| Prop 65 label required? | Yes |

Product information and application use

Horizontal sidewall sprinklers thread onto Uponor's fire sprinkler adapter fittings. Sprinklers are NSF- and UL-approved for combined plumbing and fire sprinkler systems. Sprinklers designated LF are also NSF Annex G compliant. Note: Protective plastic caps, escutcheons and covers sold separately.



| Part name | Part no. | Weight per UOM [lbs/UOM] |
|--|-----------|--------------------------|
| LF Recessed Horizontal Sidewall Sprinkler, 155F, 4.2 K-factor, White | LF74300HW | 0.15 |
| LF Recessed Horizontal Sidewall Sprinkler, 175F, 4.2 K-factor, White | LF74301HW | 0.15 |
| LF Flat Concealed Horizontal Sidewall Sprinkler, 165F, 4.0 K-factor | LF74000HS | 0.15 |

| Installation | Related applications |
|--|-------------------------------|
| Do not store sprinkler assemblies where the ambient temperature will exceed 100°F. Recessed sprinkler wrench required to assemble sprinkler and adapter. | AquaSAFE™ Fire Safety Systems |

| Footnotes | Contact information |
|-----------|---|
| - | <div>Uponor Inc. 5925 148th Street West Apple Valley, MN 55124 T 800.321.4739 F 952.891.2008</div> <div>Uponor Ltd. 6510 Kennedy Road Mississauga, ON L5T 2X4 T 888.594.7726 F 800.638.9517</div> |