
υροποι

PEX rails

| Project information | | |
|--------------------------------|-----------------|--|
| Job name: | Location: | |
| Engineer: | Date submitted: | |
| Contractor: | Submitted by: | |
| Manufacturer's representative: | Approved by: | |
| | | |

| Technical data | | |
|---|---------------------------------------|--|
| Material | Plastic | |
| Subcomponent Material | Polyethylene (post-consumer products) | |
| Product information and application use | | |

Plastic PEX Rail secures Uponor PEX tubing products to metal, concrete and wood support structures. Note: Suitable fastening hardware is required (not included).



| Part name | Part no. | Weight per UOM [lbs/UOM] |
|------------------------|----------|--------------------------|
| 1/2" PEX Rail, 6.5 ft. | A5700500 | 1.1 |
| 5/8" PEX Rail, 6.5 ft. | A5700625 | 1 |
| 3/4" PEX Rail, 6.5 ft. | A5700750 | 1.35 |

| Installation | Related applications |
|--|---|
| ay out the tube rails parallel with the floor joists (perpendicular to the tubing layout direction). Space he rails 12 inches from the edge of the wall and 36 inches on center thereafter. Fasten the rails to | Radiant Heating and Cooling Systems Turf Conditioning Systems |
| the subfloor using 1" wood screws, liquid nails or silicone. Refer to the Uponor Radiant Installation | Permafrost Prevention Systems |
| Handbook for additional information. | Snow and Ice Melt Systems |

| Footnotes | Contact information | |
|-----------|------------------------|-------------------------|
| | Uponor Inc. | Uponor Ltd. |
| | 5925 148th Street West | 6510 Kennedy Road |
| | Apple Valley, MN 55124 | Mississauga, ON L5T 2X4 |
| | T 800.321.4739 | T 888.594.7726 |
| | F 952.891.2008 | F 800.638.9517 |