Ensamblajes de colectores TruFLOW Classic con válvulas de compensación y aislamiento



| Project information | oformation | | |
|--------------------------------|-----------------|--|--|
| Job name: | Location: | | |
| Engineer: | Fecha de envío: | | |
| Contractor: | Presentada por: | | |
| Manufacturer's representative: | Approved by: | | |

Technical data

 Material
 Brass

 Manifold size
 1.25 inch

 Loop Cv
 1.9 Cv

 End type 1
 ISO 228-G 1-1/4"

 End type 2
 ISO 228-G 3/4"


Temp/pressure ratings 73 °F (23 °C) at 160 psi (11 bar) 180 °F (82 °C) at 100 psi (6.9 bar)

200 °F (93 °C) at 80 psi (5.5 bar)

Max. fluid flow rate 21 gpm Prop 65 label required? Yes

Product information and application use

The Uponor TruFLOW™ Classic Manifold system comes fully assembled. Flow balancing is controlled through manifold adjustments to the balancing valve on the supply manifold. The manifold is mounted on a durable bracket with an end cap on the supply manifold and an end cap with vent and drain on the return manifold. R32 unions on the inlet side of the manifolds allow connections to any manifold adapters offered by Uponor.



| ı | Part name | Part no. | Codes | Standards | Listings |
|---|---|----------|---------------------------|--|------------|
| | Ensamblajes de colectores TruFLOW Classic con válvulas de compensación v aislamiento | All | IMC IRC NBC of Canada UMC | CSA B137.5 R32: ISO 228-G 1¼" ASTM F877 R20: ISO 228-G ¾" | cNSFus-rfh |

Installation Related applications

TruFLOW Classic manifolds are completely assembled and ready for installation right out of the box. Use the TruFLOW Balancing Hex Key (A2620002) on the internal balancing valves of the supply manifold. Manifold is shipped with the appropriate number of TruFLOW Manifold Actuator Adapters (A2630028). Refer to the TruFLOW Classic Manifold Instruction Sheet for further information.

Radiant Heating and Cooling Systems
Permafrost Prevention Systems
Turf Conditioning Systems

Notes

Manifold loop threaded connections:

ISO 228-G 3/4" (R20)

| Footnotes | Contact information | | |
|-----------|------------------------|-------------------------|--|
| | Uponor Inc. | Uponor Ltd. | |
| | 5925 148th Street West | 6510 Kennedy Road | |
| • | Apple Valley, MN 55124 | Mississauga, ON L5T 2X4 | |
| | T 800.321.4739 | T 888.594.7726 | |
| | F 952.891.2008 | F 800.638.9517 | |