# υροποι

# Válvulas térmicas de zona

Project Information	
Job name:	Location:
Engineer:	Fecha de envío:
Contractor:	Presentada por:
Manufacturer's representative:	Approved by:

#### Technical data

Material Brass

### Product information and application use

The Uponor Thermal Zone Valve, four-wire, features  $\frac{3}{4}$ " and 1" sweat connections. It provides flow control for individual terminal units or a single-zone manifold (manifold serving one zone). The Thermal Zone Valve is assembled with the 1-watt Uponor Thermal Actuator, four-wire (A3023522) which includes an end switch for activation of a relay pump, heat plant or other auxiliary devices.

Part name	Part no.	A [inch]	B [inch]	C [inch]	Cv	End Type 1	End Type 2	Operating Temperature 1 [°F]	Operating Temperature 2 [°F]	Operating Temperature 3 [°F]	Operating temperature max. [°F]
3/4" and 1" Thermal Zone Valve	A3011075	5.874	4.122	2.173	5.3	Sweat	Sweat	73	180	200	248
1" Union Replacement Gasket	A5400012	1.181	1.181	0.118	-	-	-	-	-	-	-

Part name	Part no.	Prop 65 label required?	Weight per UOM [lbs/UOM]
3/4" and 1" Thermal Zone Valve	A3011075	Yes	2.05
1" Union Replacement Gasket	A5400012	-	0

Part name	Part no.	Codes	Standards	Listings
Válvulas térmicas de zona	All	-	ASSE 1016-T ASSE 1017	-

Installation	Related applications
	Radiant Heating and Cooling Systems
Refer to the Uponor Thermal Actuator Instruction Sheet for additional information.	Permafrost Protection Systems
	Turf Conditioning Systems

## Notes

Connections: %" sweat; 1" sweat Operating voltage 24VAC nominal, 1 watt Time to open/close 3 to 5 minutes End switch rating 24VAC, 2A resistive

Footnotes	Contact in	nformation
	Uponor Inc.	Uponor Ltd.
	5925 148th Street West	6510 Kennedy Road
	Apple Valley, MN 55124	Mississauga, ON L5T 2X4
	T 800.321.4739	T 888.594.7726
	F 952.891.2008	F 800.638.9517