

# Control de zona única en sistemas para derretir nieve

## Project information


Job name:	Location:
Engineer:	Fecha de envío:
Contractor:	Presentada por:
Manufacturer's representative:	Approved by:

## Technical data

Ambient temperature min. [F]	°f
Ambient temperature max. [F]	°f
Ambient humidity non-condensing max [%]	90
Prop 65 label required?	Yes

## Product information and application use

The Uponor Single-zone Snow Melt Control is designed to operate electric or hydronic equipment to melt snow or ice. The control has an automatic start and stop function when used with the Uponor Pavement Snow and Ice Sensor (A3040090) or Uponor Aerial Snow Sensor (A3040095). The control can be configured to operate a modulating hydronic boiler or a mixing device and features boiler protection, an idle function and warm/cold weather lockout. Accessories include a Pavement Snow and Ice Sensor (A3040090), a Pavement Snow and Ice Sensor Cup (A3040091), an Aerial Snow Sensor (A3040095) and a Slab Sensor for Aerial Snow Sensor (A3040073).



Part name	Part no.	Relay rating at 24VAC [A]
Single-zone Snow Melt Control	A3040654	2

Part name	Part no.	Codes	Standards	Listings
Control de zona única en sistemas para derretir nieve	A3040654	-	Class II wiring	-

## Installation

## Related applications

Fasten terminal connectors on the Single-zone Snow Melt Control. Refer to the Uponor Single-zone Snow Melt Control Installation and Operation Manual for more information.

Radiant Heating and Cooling Systems  
Permafrost Protection Systems  
Turf Conditioning Systems

## Notes

Power consumption:  
16 VA standby 100 VA full load  
Relay rating at 24VAC [A] :  
3.6 combined  
Modulating output:  
0-10 (dc) 500 ohm load impedance  
4-20 mA 1k max load impedance  
Sensors:  
NTC thermistor, 10

## Footnotes

## Contact information

-	Uponor Inc. 5925 148th Street West Apple Valley, MN 55124 T 800.321.4739 F 952.891.2008	Uponor Ltd. 6510 Kennedy Road Mississauga, ON L5T 2X4 T 888.594.7726 F 800.638.9517
---	---	---