Adaptadores y bujes rectos para colectores de bronce con



rosca

| Project information | |
|--------------------------------|-----------------|
| Job name: | Location: |
| Engineer: | Fecha de envío: |
| Contractor: | Presentada por: |
| Manufacturer's representative: | Approved by: |

Technical data

Material Brass

End type 1 ISO 228-G 1-1/4"


Temp/pressure ratings 73 °F (23 °C) at 160 psi (11 bar) 180 °F (82 °C) at 100 psi (6.9 bar)

200 °F (93 °C) at 80 psi (5.5 bar)

Prop 65 label required? Yes

Product information and application use

Uponor's Threaded Brass Manifold Bushings are used in TruFLOW $^{\text{TM}}$ manifolds. In radiant heating applications, the bushing transitions the R32 manifold union nut to 1" national pipe thread (NPT) and $^{3}\!4''$ threaded connections (PEX or Multi-layer Composite (MLC) tubing with QS-style fittings).



| Part name | Part no. | End Type 2 |
|---|----------|------------|
| Threaded Brass Manifold Bushing, R32 Male x 3/4" Female NPT | A2133275 | FNPT 3/4" |
| Threaded Brass Manifold Bushing, R32 Male x 1" Female NPT | A2123210 | FNPT 1" |

| Part name | Part no. | Codes | Standards | Listings |
|--|----------|---------------------------|--|------------|
| Adaptadores y bujes rectos para colectores de bronce con rosca | All | IMC IRC NBC of Canada UMC | CSA B137.5 R32: ISO 228-G 1¼" ASTM F877 | cNSFus-rfh |

Installation Related applications

Thread directly into Uponor TruFLOW manifolds. For additional information, refer to the TruFLOW Manifold Instruction Sheet or the Uponor Radiant Floor Heating Installation Handbook.

Radiant Heating and Cooling Systems
Permafrost Protection Systems
Turf Conditioning Systems

| Footnotes | Contact information | | |
|-----------|------------------------|-------------------------|--|
| | Uponor Inc. | Uponor Ltd. | |
| | 5925 148th Street West | 6510 Kennedy Road | |
| • | Apple Valley, MN 55124 | Mississauga, ON L5T 2X4 | |
| | T 800.321.4739 | T 888.594.7726 | |
| | F 952.891.2008 | F 800.638.9517 | |