Colectores con válvula de cobre y válvulas de bola y compensación ProPEX



Project information	
Job name:	Location:
Engineer:	Fecha de envío:
Contractor:	Presentada por:
Manufacturer's representative:	Approved by:

Technical data

Material Copper Manifold size 2 inch

Temp/pressure ratings 73 °F (23 °C) at 160 psi (11 bar) 180 °F (82 °C) at 100 psi (6.9 bar) 200 °F (93 °C) at 80 psi (5.5 bar)

200 °F (93 °C) at 80 psi (5.5 bar) 210 °F (99 °C) at 149 psi (10.3 bar)

Max. fluid flow rate 45 gpm Prop 65 label required? Yes

Product information and application use

Uponor offers 2" Copper Valved Manifold with ProPEX® Ball and Balancing Valves for radiant heating projects. The manifold has a 2" Copper Sweat Fitting Adapter supply connection and 34" nominal branches. This 12-outlet manifold is preassembled with 5%" or 34" ProPEX balancing valve connections.

This product is made to order, please contact customer service for lead time.



Part name	Part no.	A [inch]	B [inch]	C [inch]	Cv Branch	End Type 1	Weight per UOM [lbs/UOM]
2" x 4' Copper Valved Manifold with 5/8" ProPEX Ball and Balancing Valves, 12 outlets	Q2821263	48	7.79	2.633	6.6	ProPEX 5/8"	15.25
2" x 4' Copper Valved Manifold with 3/4" ProPEX Ball and Balancing Valves, 12 outlets	Q2821275	48	7.871	2.633	6.7	ProPEX 3/4"	15.25

Part name	Part no.	Codes	Standards	Listings
Colectores con válvula de cobre y				
válvulas de bola y compensación	All	-	CSA B137.5 ASTM F877	cNSFus-rfh
ProPEX				

Installation Related applications

Install using any product designed to mount 2" copper pipe as a mounting bracket. Refer to the Uponor Radiant Floor Heating Installation Handbook for additional information.

Radiant Heating and Cooling Systems
Permafrost Protection Systems
Turf Conditioning Systems

lotes

Ball Valve Cv " outlet: 6.60 Ball Valve Cv ¾" outlet: 6.70

Footnotes	Contact information		
	Uponor Inc.	Uponor Ltd.	
	5925 148th Street West	6510 Kennedy Road	
	Apple Valley, MN 55124	Mississauga, ON L5T 2X4	
	T 800.321.4739	T 888.594.7726	
	F 952.891.2008	F 800.638.9517	