

# Medidores de temperatura del circuito para colectores

## TruFLOW



### Project information

Job name:	Location:
Engineer:	Fecha de envío:
Contractor:	Presentada por:
Manufacturer's representative:	Approved by:

### Technical data

Material	Brass
Temp/pressure ratings	73 °F (23 °C) at 160 psi (11 bar) 180 °F (82 °C) at 100 psi (6.9 bar) 200 °F (93 °C) at 80 psi (5.5 bar)
Prop 65 label required?	Yes

### Product information and application use

TruFLOW™ Manifold Loop Temperature Gauge comes with a QS20 female union on one end and a QS20 male on the other end. Part includes temperature gauge well and removable temperature gauge.



Part name	Part no.	End Type 1	A [inch]	B [inch]	C [inch]	Weight per UOM [lbs/UOM]
TruFLOW Manifold Loop Temperature Gauge	A2610020	ISO 228-G	-	-	-	0.4
Temperature Gauge with Well, replacement part	A2610120	-	1.575	1.575	1.575	0.1

Part name	Part no.	Codes	Standards	Listings
Medidores de temperatura del circuito para colectores TruFLOW	All	-	ASTM F877/R20: ISO 228-G ¾"	-

Installation	Related applications
Install the TruFLOW Manifold Loop Temperature Gauge Nipple on the R20 loop outlet on the return side of the TruFLOW Manifold assembly. Install the desired fitting assembly on the outlet of the TruFLOW Manifold Loop Temperature Gauge Nipple. Use only TruFLOW Manifolds. Accessories: Temperature Gauge with Well, replacement part (A2610120). Refer to the Uponor Radiant Installation Handbook for additional information.	Radiant Heating and Cooling Systems

### Notes

Connection:  
R20 QS-style

Footnotes	Contact information
-	<div>Uponor Inc. 5925 148th Street West Apple Valley, MN 55124 T 800.321.4739 F 952.891.2008</div> <div>Uponor Ltd. 6510 Kennedy Road Mississauga, ON L5T 2X4 T 888.594.7726 F 800.638.9517</div>