Tapas con conducto de ventilación y drenaje para colectores de calefacción de EP



Project information	
Job name:	Location:
Engineer:	Fecha de envío:
Contractor:	Presentada por:
Manufacturer's representative:	Approved by:

Product information and application use

The Engineered Plastic (EP) Heating Manifold End Cap with Vent and Drain (A2671250) allows filling and purging at the EP Heating Manifold for use in hydronic radiant heating and cooling systems. Only use propylene glycol in radiant systems with EP Heating Manifolds; never use methanol or ethylene glycol.



Installation Related applications

Hand-tighten the end cap to the manifold. For additional information, refer to the instruction sheet. Note: Use only propylene glycol in radiant heating and cooling systems with EP Heating Manifolds; never use methanol or ethylene glycol. Refer to the EP Heating Manifold Installation Guide for a complete chemical compatibility list.

Radiant Heating and Cooling Systems
Permafrost Protection Systems
Turf Conditioning Systems

 Footnotes
 Contact information

 Uponor Inc.
 Uponor Ltd.

 5925 148th Street West
 6510 Kennedy Road

 Apple Valley, MN 55124
 Mississauga, ON L5T 2X4

 T 800.321.4739
 T 888.594.7726

 F 952.891.2008
 F 800.638.9517