

Válvulas de bola de bronce ProPEX

Project information	
Job name:	Location:
Engineer:	Fecha de envío:
Contractor:	Presentada por:
Manufacturer's representative:	Approved by:

Technical data


Temp/pressure ratings $\,$ 73 °F (23 °C) at 160 psi (11 bar)

180 °F (82 °C) at 100 psi (6.9 bar) 200 °F (93 °C) at 80 psi (5.5 bar)

Prop 65 label required? Yes

Product information and application use

Uponor ProPEX® Brass Ball Valve is a cost-effective alternative for radiant heating/cooling and hydronic piping applications. Both ends are manufactured with the ProPEX fitting for connections to Uponor PEX pipe. The full-port valves are compatible with propylene glycol mixtures up to 50%. Stem extensions can be installed to accommodate up to 2" of pipe insulation. Note: ProPEX Brass Ball Valves are not approved for potable-water applications.



Part name	Part	A	B	C	D	E	F	G	H	l	J
	no.	[inch]									
ProPEX Brass Ball Valve 2" PEX x 2" PEX	A3202020	2.147	2.834	3.374	5.57	1.467	1.103	9.448	4.831	2.915	7.128

Part name	Part no.	Weight per UOM [lbs/UOM]
ProPEX Brass Ball Valve 2" PEX x 2" PEX	A3202020	4.18

Part name	Part no.	Codes	Standards	Listings
Válvulas de bola de bronce ProPEX	A3202020	IMC UMC	ASTM F1960 CSA B137.5 NSF/ANSI 14 ASTM F877 NSF/ANSI 359	cNSFus-rfh

Installation	Related applications			
Install valve according to local building code. Do not dismantle. Refer to the Uponor Hydronic Piping Design Assistance Manual (HPDAM) or the Uponor Radiant Floor Heating Installation Handbook for additional information.	Hot water distribution			
	Hydronic heating and cooling systems			
	Hydronic Piping Systems			
	Hydronic Radiant Heating and Cooling Systems			
	PEX-a Plumbing Systems			
	Plumbing Systems			
	Pre-Insulated Pipe Systems			
	Radiant Floor Heating and Cooling Systems			
	Radiant Heating and Cooling Systems			

Footnotes	Contact ir	Contact information		
	Uponor Inc.	Uponor Ltd.		
	5925 148th Street West	6510 Kennedy Road		
•	Apple Valley, MN 55124	Mississauga, ON L5T 2X4		
	T 800.321.4739	T 888.594.7726		
	F 952.891.2008	F 800.638.9517		