

Medidores de flujo visuales TruFLOW

Project information

| | |
|--------------------------------|-----------------|
| Job name: | Location: |
| Engineer: | Fecha de envío: |
| Contractor: | Presentada por: |
| Manufacturer's representative: | Approved by: |

Product information and application use

Use the TruFLOW™ Visual Flow Meter on TruFLOW Jr. and TruFLOW Classic Manifolds to accurately measure the flow of hydronic radiant loops. The meter is available in a low range (A2640015), which measures 0.15 to 0.8 gpm and a high range (A2640027), which measures 0.25 to 2.0 gpm.



| Part name | Part no. | Cv | Material group | Subcomponent Material | End Type 1 | End Type 2 | Prop 65 label required? |
|---|----------|------|----------------|-----------------------|------------|------------|-------------------------|
| TruFLOW Visual Flow Meter, 0.15 to 0.8 gpm | A2640015 | 1.23 | Brass | Pyrex Glass | ISO 228-G | ISO 228-G | Yes |
| TruFLOW Visual Flow Meter, 0.25 to 2.0 gpm | A2640027 | 1.51 | Brass | Pyrex Glass | ISO 228-G | ISO 228-G | Yes |
| Replacement O-ring for TruFLOW Flow/Temperature Meter | A2620009 | - | - | - | - | - | - |

| Part name | Part no. | Codes | Standards | Listings |
|-------------------------------------|----------|-------|-----------------------------|----------|
| Medidores de flujo visuales TruFLOW | All | - | ASTM F877 R20: ISO 228-G ¾" | - |

| Installation | Related applications |
|--------------|----------------------|
|--------------|----------------------|

Assemble the TruFLOW Visual Flow Meter on the return manifold and observe that the water flows in the same direction as the arrow on the body of the meter. The TruFLOW Visual Flow Meter may be installed in a vertical or horizontal position. Do not install the TruFLOW Visual Flow Meter upside-down (arrow pointing downward) as it will affect the accuracy of the reading. Do not use any solvent-based cleaner to clean the measuring windows.

- Radiant Heating and Cooling Systems
- Permafrost Protection Systems
- Turf Conditioning Systems

Notes

Precision: +/-0.05gpm
Measuring Range: 0.15 gpm to 0.8 gpm
Connection:
R20 QS-style

Precision: +/-0.05gpm
Measuring Range: 0.40 gpm to 2.0 gpm
Connection:
R20 QS-style

| Footnotes | Contact information |
|-----------|---------------------|
|-----------|---------------------|

| | | |
|---|---|---|
| - | Uponor Inc. 5925 148th Street West Apple Valley, MN 55124 T 800.321.4739 F 952.891.2008 | Uponor Ltd. 6510 Kennedy Road Mississauga, ON L5T 2X4 T 888.594.7726 F 800.638.9517 |
|---|---|---|