

# Tramos individuales de colectores de calefacción de EP con válvula de compensación y medidor de flujo



## Project information

Job name:	Location:
Engineer:	Fecha de envío:
Contractor:	Presentada por:
Manufacturer's representative:	Approved by:

## Technical data

Subcomponent Material	Manifold: PA66-GF30 Valve Insert, Handwheels: POM Metal Inserts: Brass C38500 Axel: Stainless Steel Spring: Stainless Steel O-ring: EPDM
Loop Cv	1.4 Cv
End type 1	ISO 228-G 3/4"
Temp/pressure ratings	140 °F (60 °C) at 87 psi (6 bar) 158 °F (70 °C) at 72 psi (5 bar) 176 °F (80 °C) at 58 psi (4 bar) 194 °F (90 °C) at 44 psi (3 bar)
Operating temperature min. [°F]	44.6 °f
Max. fluid flow rate	15.4 gpm
Prop 65 label required?	Yes



## Product information and application use

The Engineered Polymer (EP) Heating Manifold Single Section with Balancing Valve and Flow Meter (A2670003) adds additional loops to an EP Heating Manifold assembly for use in hydronic radiant heating and cooling systems. Use only propylene glycol in radiant systems with EP Heating Manifolds; never use ethylene glycol.

Installation	Related applications
Select the proper bracket spacing for the manifold and mount the bracket to the wall. Snap the manifold to the bracket. See the installation manual for complete instructions. Note: Use only propylene glycol in radiant heating and cooling systems with EP Heating Manifolds; never use ethylene glycol. Refer to the EP Heating Manifold Installation Guide for a complete chemicals list.	Radiant Heating and Cooling Systems Permafrost Protection Systems Turf Conditioning Systems

## Notes

Adaptable Actuators:

EP Heating Manifold, two-wire Actuator (A3030522); Thermal Actuator, four-wire (A3010522) with EP Heating Manifold Actuator Adaptor (A2671300)

Connection Dimensions: R32

Footnotes	Contact information
-	Uponor Inc. 5925 148th Street West Apple Valley, MN 55124 T 800.321.4739 F 952.891.2008
	Uponor Ltd. 6510 Kennedy Road Mississauga, ON L5T 2X4 T 888.594.7726 F 800.638.9517