

Conectores en T de PP-RCT de Uponor para agua potable caliente (fusión a tope)



Project information

Job name:	Location:
Engineer:	Fecha de envío:
Contractor:	Presentada por:
Manufacturer's representative:	Approved by:


Technical data

Temp/pressure ratings	73 °F (23 °C) at 265 psi (18.27 bar)
	140 °F (60 °C) at 150 psi (10.34 bar)
	180 °F (82 °C) at 100 psi (6.9 bar)

Product information and application use

Use Uponor PP-RCT hot potable pipe to convey water for hot potable plumbing applications. The fiber layer coextruded into the mid-wall of the pipe to reduce expansion/contraction with temperature changes also makes the pipe acceptable for use in hydronic heating and cooling applications.

Note: Temperature and pressure ratings stated are hydrostatic ratings. For domestic hot-water (DHW) and DHW recirculation installations, operating conditions should not exceed 140°F (60°C) at 80 psi (5.5 bar) in accordance with ASTM F2023. For additional information regarding application-specific temperature and pressure ratings, refer to the Uponor PP-RCT Piping Systems Manual, the Uponor PP-RCT Piping Systems Installation Guide, and the Uponor PP-RCT DHW Systems Design, Installation, and Operation Guidelines.



Part name	Part no.	End Type 1	End Type 2	End Type 3	Material group
Uponor PP-RCT Tee, Hot Potable, 6" x 6" x 6", SDR 9	PR947560	Butt 6"	Butt 6"	Butt 6"	-
Uponor PP-RCT Tee, Hot Potable, 8" x 8" x 8", SDR 9	PR947580	Butt 8"	Butt 8"	Butt 8"	PP-RCT

Part name	Part no.	Codes	Standards	Listings
Conectores en T de PP-RCT de Uponor para agua potable caliente (fusión a tope)	All	UPC IRC IPC NPC of Canada UMC CMC CPC IMC	NSF/ANSI/CAN 61 ASTM E84 NSF/ANSI 14 NSF/ANSI 51 ASTM F2389 CSA B137.11	ICC-ES-PMG 1106 IAPMO-R&T 8358 QAI P321-5 IAPMO K-12775

Installation

Related applications

Use approved butt-fusion connection methods. Refer to the Uponor PP-RCT manual for complete details.

Note: Temperature and pressure ratings stated are hydrostatic ratings. For domestic hot-water (DHW) and DHW recirculation installations, operating conditions should not exceed 140°F (60°C) at 80 psi (5.5 bar) in accordance with ASTM F2023. For additional information regarding application-specific temperature and pressure ratings, refer to the Uponor PP-RCT Piping Systems Manual, the Uponor PP-RCT Piping Systems Installation Guide, and the Uponor PP-RCT DHW Systems Design, Installation, and Operation Guidelines.

Domestic water systems
Hydronic heating and cooling systems

Footnotes

Contact information

-	Uponor Inc. 5925 148th Street West Apple Valley, MN 55124 T 800.321.4739 F 952.891.2008	Uponor Ltd. 6510 Kennedy Road Mississauga, ON L5T 2X4 T 888.594.7726 F 800.638.9517
---	---	---