

## Antena Smatrix Pulse (A-265), piezas de reemplazo


Project information	
Job name:	Location:
Engineer:	Fecha de envío:
Contractor:	Presentada por:
Manufacturer's representative:	Approved by:

l echnical data	
Operating temperature min. [°F]	32 °f
Operating temperature may [9E]	112 of

Operating temperature max. [°F] 113 °f Ambient temperature min. [F] -4 °f Ambient temperature max. [F] 158 °f Ambient temperature max. [F] 85 Prop 65 label required? Yes

## Product information and application use

Use the Smatrix Pulse Antenna (A-265) replacement part to replace the antenna in the A380265A Smatrix Pulse Controller with Antenna. Smatrix Pulse provides precise wireless control of radiant floor heating as well as forced-air heating and cooling systems in one solution. The A380265A Smatrix Pulse Controller (X-265) with Antenna (A-265) connects up to six (6) thermostats and eight (8) actuators. The controller operates the actuators, which, in turn, affect the flow of the supply water to change the indoor temperature using information transmitted from the registered thermostats and system parameters.



ETHERNET CABLE LENGTH NOT TO SCALE

Part name	Part no.	A [inch]	B [inch]	C [inch]	Operating voltage AC [VAC]	Weight per UOM [lbs/UOM]
Smatrix Pulse Antenna (A-265), replacement part	A3801265	4.331	1.181	0.394	115	0.28

Part name	Part no.	Codes	Standards	Listings
Antena Smatrix Pulse (A-265), piezas de reemplazo	A3801265	-	IC RSS-210 ICC RSS-Gen FCC 47 CFR Part 15	IC 7664A-SM4NA0 FCC ID V9MSM4NA0

Installation Related	applications
----------------------	--------------

Radiant

Refer to the Smatrix Pulse Installation and Operation Manual for installation information. Hydronic Heating & Cooling

Tools & Accessories

Footnotes	Contact information		
	Uponor Inc.	Uponor Ltd.	
	5925 148th Street West	6510 Kennedy Road	
•	Apple Valley, MN 55124 Mississauga, ON L5T 2X4		
	T 800.321.4739	T 888.594.7726	
	F 952.891.2008	F 800.638.9517	