

Xpress Trak

Project Information


| | |
|--------------------------------|-----------------|
| Job name: | Location: |
| Engineer: | Fecha de envío: |
| Contractor: | Presentada por: |
| Manufacturer's representative: | Approved by: |

Technical data

| | |
|---------------------------------|------------------------------|
| Material | Aluminum Laminate w/XPS Foam |
| Operating temperature min. [°F] | 50 °f |
| Operating temperature max. [°F] | 150 °f |
| R value | 3.13 |
| Prop 65 label required? | Yes |

Product Information and application use

Designed for residential new construction and remodels, Xpress Trak™ is a radiant panel that features lightweight XPS foam laminated with aluminum for exceptional heat-transfer capability. Straight runs and return bends are integrated into one panel for quick, easy ordering. To install, simply adhere the panels to a wood subfloor or a concrete slab.



| Part name | Part no. | A [inch] | B [inch] | C [inch] | D [inch] | E [inch] | F [inch] | G [inch] | Weight per UOM [lbs/UOM] |
|--|----------|----------|----------|----------|----------|----------|----------|----------|--------------------------|
| Xpress Trak Radiant Panel, 6" o.c., 4 runs | A5070641 | 23.622 | 47.244 | 0.63 | 2.953 | 5.906 | 1.488 | 1.457 | 1.45 |

Installation

Use water-based sealant to adhere the panels to a wood subfloor or a concrete slab. Then, press the 5/16" Wirsbo hePEX™ pipe into the panel grooves using hands or feet. For further information, refer to the Xpress Trak Installation Guide.

Related applications

Radiant heating

Footnotes

-

Contact information

Uponor Inc.
5925 148th Street West
Apple Valley, MN 55124
T 800.321.4739
F 952.891.2008

Uponor Ltd.
6510 Kennedy Road
Mississauga, ON L5T 2X4
T 888.594.7726
F 800.638.9517