Jauges de température pour boucle de collecteur TruFLOW

Renseignements sur le projet

Nom du poste :	Lieu :
Ingénieur :	Date de soumission:
Entrepreneur :	Présentée par:
Représentant du fabricant :	Approuvé par :

Données techniques

Material	Brass
Temp/pressure ratings	73 °F (23 °C) at 160 psi (11 bar) 180 °F (82 °C) at 100 psi (6.9 bar) 200 °F (93 °C) at 80 psi (5.5 bar)
Prop 65 label required?	Yes



Informations sur le produit et utilisation de l'application

TruFLOW Manifold Loop Temperature Gauge comes with a QS20 female union on one end and a QS20 male on the other end. Part includes temperature gauge well and removable temperature gauge.

	Nom de la pièce	Numéro de pièce	End Type 1	A [inch]	B [inch]	C [inch]	Weight per UOM [lbs/UOM]
✔	TruFLOW Manifold Loop Temperature Gauge	A2610020	ISO 228-G	-	-	-	0.4
	Temperature Gauge with Well, replacement part	A2610120	-	1.575	1.575	1.575	0.1

Nom de la pièce	Numéro de pièce	Les codes	Normes	Annonces
Jauges de température pour boucle de collecteur TruFLOW	All	-	ASTM F877|R20: ISO 228-G ¾"	-

L'installation

Install the TruFLOW Manifold Loop Temperature Gauge Nipple on the R20 loop outlet on the return side of the TruFLOW Manifold assembly. Install the desired fitting assembly on the outlet of the TruFLOW Manifold Loop Temperature Gauge Nipple. Use only TruFLOW Manifolds. Accessories: Temperature Gauge with Well, replacement part (A2610120). Refer to the Uponor Radiant Installation Handbook for additional information.

Applications connexes

Radiant Heating and Cooling Systems

Remarques :

Connection:
R20 QS-style

Notes de bas de page

-

Coordonnées de la personne-ressource

Uponor Inc.
5925 148th Street West
Apple Valley, MN 55124
T 800.321.4739
F 952.891.2008

Uponor Ltd.
6510 Kennedy Road
Mississauga, ON L5T 2X4
T 888.594.7726
F 800.638.9517

© 2026 Uponor Amérique du Nord. Tous droits réservés