

# Débitmètre visuel TruFLOW

## Renseignements sur le projet

Nom du poste :	Lieu :
Ingénieur :	Date de soumission:
Entrepreneur :	Présentée par:
Représentant du fabricant :	Approuvé par :

## Données techniques

Material	Brass
End type 1	ISO 228-G 3/4"
End type 2	ISO 228-G 3/4"
Temp/pressure ratings	73 °F (23 °C) at 160 psi (11 bar) 180 °F (82 °C) at 100 psi (6.9 bar) 200 °F (93 °C) at 80 psi (5.5 bar)
Prop 65 label required?	Yes

## Informations sur le produit et utilisation de l'application

Use the TruFLOW™ Visual Flow Meter on TruFLOW Jr. and TruFLOW Classic Manifolds to accurately measure the flow of hydronic radiant loops. The meter is available in a low range (A2640015), which measures 0.15 to 0.8 gpm and a high range (A2640027), which measures 0.25 to 2.0 gpm.



Nom de la pièce	Numéro de pièce	A [inch]	B [inch]	C [inch]	Cv	Weight per UOM [lbs/UOM]
Replacement O-ring for TruFLOW Flow/Temperature Meter	A2620009	0.59	0.59	0.103	-	0
TruFLOW Visual Flow Meter, 0.15 to 0.8 gpm	A2640015	2.623	1.32	1.178	1.23	0.28
TruFLOW Visual Flow Meter, 0.25 to 2.0 gpm	A2640027	2.677	1.035	1.035	1.51	0.28

## L'installation

Assemble the TruFLOW Visual Flow Meter on the return manifold and observe that the water flows in the same direction as the arrow on the body of the meter. The TruFLOW Visual Flow Meter may be installed in a vertical or horizontal position. Do not install the TruFLOW Visual Flow Meter upside-down (arrow pointing downward) as it will affect the accuracy of the reading. Do not use any solvent-based cleaner to clean the measuring windows.

## Applications connexes

- Radiant Heating and Cooling Systems
- Permafrost Protection Systems
- Turf Conditioning Systems

## Les codes

## Normes

## Annonces

- ASTM F877/R20: -

## Remarques :

Precision: +/-0.05gpm  
Measuring Range: 0.15 gpm to 0.8 gpm  
Connection:  
R20 QS-style

Precision: +/-0.05gpm  
Measuring Range: 0.40 gpm to 2.0 gpm  
Connection:  
R20 QS-style

## Notes de bas de page

## Coordonnées de la personne-ressource

-	<p>Uponor Inc. 5925 148th Street West Apple Valley, MN 55124 T 800.321.4739 F 952.891.2008</p>	<p>Uponor Ltd. 6510 Kennedy Road Mississauga, ON L5T 2X4 T 888.594.7726 F 800.638.9517</p>
---	--	--