

# Collecteurs sans vanne TruFLOW Jr.

## Renseignements sur le projet

|                             |                     |
|-----------------------------|---------------------|
| Nom du poste :              | Lieu :              |
| Ingénieur :                 | Date de soumission: |
| Entrepreneur :              | Présentée par:      |
| Représentant du fabricant : | Approuvé par :      |

## Données techniques

|                         |  |
|-------------------------|--|
| Material                | Brass  |
| Manifold size           | 1 inch   |
| Loop Cv                 | 1.9 Cv   |
| End type 1              | ISO 228-G 1-1/4"   |
| End type 2              | ISO 228-G 3/4"   |
| Temp/pressure ratings   | 73 °F (23 °C) at 160 psi (11 bar)<br>180 °F (82 °C) at 100 psi (6.9 bar)<br>200 °F (93 °C) at 80 psi (5.5 bar) |
| Max. fluid flow rate    | 14 gpm   |
| Prop 65 label required? | Yes  |



## Informations sur le produit et utilisation de l'application

Use the TruFLOW™ Jr. Valveless Manifold with either the TruFLOW Jr. Manifold with Isolation Valves or the TruFLOW Jr. Manifold with Balancing Valves to complete the manifold set. The TruFLOW Jr. Valveless Manifold does not feature flow balancing or isolation capability. Manifolds are available in 2-, 3- and 4-loop configurations. The manifold body ends have R32 unions and the loop outlets have R20 male threads.

| Nom de la pièce               | Numéro de pièce | C [inch] | Weight per UOM [lbs/UOM] |
|-------------------------------|-----------------|----------|--------------------------|
| TruFLOW Jr. Valveless, 2-loop | A2663202        | -        | 2.1                      |
| TruFLOW Jr. Valveless, 3-loop | A2663203        | -        | 2.8                      |
| TruFLOW Jr. Valveless, 4-loop | A2663204        | 2.3      | 3.4                      |

## L'installation

Refer to the TruFLOW Jr. Manifold Instruction Sheet or the Uponor Complete Design Assistance Manual for additional information.

## Applications connexes

Radiant Heating and Cooling Systems  
Permafrost Prevention Systems  
Turf Conditioning Systems

## Les codes

IMC|IRC|NBC of Canada|UMC

## Normes

CSA B137.5|R32:

## Annonces

cNSFus-rfh

## Remarques :

Manifold body threaded connections:  
R32  
Manifold loop threaded connections: R20

## Notes de bas de page

## Coordonnées de la personne-ressource

Uponor Inc.  
5925 148th Street West  
Apple Valley, MN 55124  
T 800.321.4739  
F 952.891.2008

Uponor Ltd.  
6510 Kennedy Road  
Mississauga, ON L5T 2X4  
T 888.594.7726  
F 800.638.9517