

Collecteurs de retour TruFLOW Jr. avec vannes d'isolement

Renseignements sur le projet

Nom du poste :	Lieu :
Ingénieur :	Date de soumission:
Entrepreneur :	Présentée par:
Représentant du fabricant :	Approuvé par :

Données techniques

Material	Brass
Manifold size	1 inch
Loop Cv	1.9 Cv
End type 1	ISO 228-G 1-1/4"
End type 2	ISO 228-G 3/4"
Temp/pressure ratings	73 °F (23 °C) at 160 psi (11 bar) 180 °F (82 °C) at 100 psi (6.9 bar) 200 °F (93 °C) at 80 psi (5.5 bar)
Max. fluid flow rate	14 gpm
Prop 65 label required?	Yes



Informations sur le produit et utilisation de l'application

Use the TruFLOW™ Jr. Manifold with Isolation Valves with either the TruFLOW Jr. Manifold with Balancing Valves or the TruFLOW Jr. Valveless Manifold to complete the manifold set. The TruFLOW Jr. Manifold with Isolation Valves allows quick isolation of the loop by turning the black cap on the top of the manifold. For multiple zoning on the manifold, remove the black caps and replace with Uponor Thermal Actuators or Motorized Valve Actuators (MVAs). TruFLOW Manifold Actuator Adapters are included for mounting Thermal Actuators or MVAs. Manifolds are available in 2-, 3- and 4-loop configurations. The manifold body ends have R32 unions and the loop outlets have R20 male threads.

Nom de la pièce	Numéro de pièce	B [inch]	C [inch]	Weight per UOM [lbs/UOM]
TruFLOW Jr. Isolation Valves, 2-loop	A2663222	-	-	2.6
TruFLOW Jr. Isolation Valves, 3-loop	A2663223	-	-	3.4
TruFLOW Jr. Isolation Valves, 4-loop	A2663224	9.6	4.13	4.3

L'installation

Manifold is shipped with the appropriate number of actuator adapters (A2630028). Refer to the TruFLOW Jr. Manifold Instruction Sheet or the Uponor Complete Design Assistance Manual for additional information.

Applications connexes

Radiant Heating and Cooling Systems
Permafrost Prevention Systems
Turf Conditioning Systems

Les codes

IMC|IRC|NBC of Canada|UMC

Normes

CSA B137.5|R32:

Annonces

cNSFus-rfh

Remarques :

Manifold body threaded connections:
R32
Manifold loop threaded connections: R20

Notes de bas de page

Coordonnées de la personne-ressource

Uponor Inc.
5925 148th Street West
Apple Valley, MN 55124
T 800.321.4739
F 952.891.2008

Uponor Ltd.
6510 Kennedy Road
Mississauga, ON L5T 2X4
T 888.594.7726
F 800.638.9517